

Advisory Clauses

- (a) resolve any land issue relating to the development with other concerned owner(s) of the Site;
- (b) note DLO/YL, LandsD's comments that the Site comprises Old Schedule Agricultural Lots held under the Block Government Lease which contains the restriction that no structures are allowed to be erected without the prior approval of the Government. The Site is accessible from Fan Kam Road via Government Land (GL) and private land. His office provides no maintenance work for the GL involved and does not guarantee any right-of-way over the GL to the Site. The Site falls within Shek Kong Airfield Height Restriction Area (SKAHRA). The height of the proposed structure shall not exceed the relevant airfield height limit within SKAHRA. The STW holders(s) will need to apply to his office for modification of the STW conditions where appropriate. The owner(s) of the lot without STW will need to apply to his office to permit the structures to be erected or regularize any irregularities on site, if any. Besides, given the proposed use is temporary in nature, only application for regularization or erection of temporary structure(s) will be considered. No construction of New Territories Exempted Building(s) will be considered or allowed. Applications for any of the above will be considered by LandsD acting in the capacity as the landlord or lessor at its sole discretion and there is no guarantee that such application will be approved. If such application(s) is approved, it will be subject to such terms and conditions, including among others the payment of premium or fee, as may be imposed by the LandsD;
- (c) note C for T's comments that the Site is connected to the public road network via a section of a local access road which is not managed by Transport Department. The land status of the local access road should be checked with the LandsD. Moreover, the management and maintenance responsibilities of the local access road should be clarified with the relevant lands and maintenance authorities accordingly;
- (d) note CE/NTW, HyD's comments that his department does not and will not maintain the accesses connecting the Site and Fan Kam Road. Adequate drainage measures should be provided to prevent surface water running from the Site to the nearby public roads and drains;
- (e) follow the relevant mitigation measures and requirements in the latest "Code of Practice on Handling the Environmental Aspects of Temporary uses and Open Storage Sites" issued by the EPD;
- (f) note D of FS' comments that in consideration of the design/nature of the proposal, FSIs are anticipated to be required. Therefore, the applicant is advised to submit relevant layout plans incorporated with the proposed FSIs to his department for approval. The layout plans should be drawn to scale and depicted with dimensions and nature of occupancy. The location of where the proposed FSI to be installed should be clearly marked on the layout plans. The applicant is reminded that if the proposed structure(s) is required to comply with the Buildings Ordinance (BO) (Cap. 123), detailed fire service requirements will be formulated upon receipt of formal submission of general building plans;
- (g) note CE/C, WSD's comments that for provision of water supply to the development, the applicant may need to extend his/her inside services to the nearest suitable government water

mains for connection. The applicant shall resolve any land matter (such as private lots) associated with the provision of water supply and shall be responsible for the connection, operation and maintenance of the inside services within the private lots to WSD's standards; and

- (h) note CBS/NTW, BD's comments that if the existing structures (not being a New Territories Exempted House) are erected on leased land without the approval of BD, they are unauthorised building works (UBW) under the BO and should not be designated for any proposed use under the application. For UBW erected on leased land, enforcement action may be taken by BD to effect their removal in accordance with BD's enforcement policy against UBW as and when necessary. The granting of any planning approval should not be construed as an acceptance of any existing building works or UBW on the Site under BO. Before any new building works (including containers/open sheds as temporary buildings and land filling) are to be carried out on the Site, prior approval and consent of BD should be obtained, otherwise they are UBW. An Authorized Person (AP) should be appointed as the co-ordinator for the proposed building works in accordance with BO. The Site shall be provided with means of obtaining access thereto from a street and emergency vehicular access in accordance with Regulations 5 and 41D of the Building (Planning) Regulations (B(P)R) respectively. If the Site does not abut on a specified street of not less than 4.5m wide, its permitted development intensity shall be determined under Regulation 19(3) of the B(P)R at the building plan submission stage.