

Responses-to-Comments

Temporary Warehouse for a Period of 3 Years in “Residential (Group B) 3” Zone, Lot 2238 S.A RP (Part) in D.D.124 and Adjoining Government Land, Hung Shui Kiu, Yuen Long, New Territories

(Application No. A/HSK/493)

(i) A RtoC Table:

Departmental Comments		Applicant’s Responses
1. Comments of the Director of Fire Services (D of FS) (Contact Person: Mr. CHAU Nai-yin; Tel: 2733 7781)		
(i)	The provision of 4 kg dry powder type fire extinguisher shall be specified in the FS Notes;	Noted. A revised fire service installations proposal is submitted by the applicant for your consideration please (Annex I).
(ii)	Exit signs as mentioned in FS Notes item 2 shall be clearly marked on the plan; and	
(iii)	'F.S Pump Room' as mentioned in FS Notes item 8 shall be revised to 'FS & Sprinkler Pump Room' to tally with the information on the plan.	