



營業時間： 星期一至星期日， 08:00am-18:00pm
(公眾假期照常營業)

A	寫字樓 (6.1m x 2.44m x 2.62m高)	14.88m ²
B	員工休息室 (6.1m x 2.44m x 2.62m高)	14.88m ²
C	洗手間 (2.1m x 1.8m x 不低於3m)	3.78m ²
D	污水及化糞系統 (1.2x1.2x1.1m高)	1.44m ²
	(3.6 x 1.2 x 1.1m高)	4.32m ²
E	蔬菜貯存室 (5米高)	97.39m ²
F	蔬果零售區 (冷氣房三面密封5米高)	110.67m ²
G	乾貨零售區 (設施隔5m高)(三面通風)	182.82m ²
申請範圍		共 695.48m ²

圖示: H

C _c	4.5公斤二氧化碳滅火器
S _{sa}	獨立火警偵測器
-----	申請範圍

FIRE SERVICES NOTES

- PORTABLE FIRE EXTINGUISHERS SHALL BE PROVIDED AS INDICATED ON THE BUILDING PLANS.
- ALL LININGS FOR ACOUSTIC, THERMAL INSULATION PURPOSES IN DUCTINGS AND CONCEALED LOCATIONS SHALL BE OF CLASS 1 OR CLASS 2 RATE OF SURFACE SPREAD OF FLAME AS PER BRITISH STANDARD 476: PART 7 OR ITS INTERNATIONAL EQUIVALENT, OR BE BROUGHT UP TO THAT STANDARD BY USE OF AN APPROVED FIRE RETARDANT PRODUCT.
- ALL LINING FOR ACOUSTIC, THERMAL INSULATION PURPOSES WITHIN THE PROTECTED MEANS OF ESCAPE SHALL BE OF CLASS 1 OR CLASS 2 RATE OF SURFACE SPREAD OF FLAME AS PER BRITISH STANDARD 476: PART 7 OR ITS INTERNATIONAL EQUIVALENT, OR BE BROUGHT UP TO THAT STANDARD BY USE OF AN APPROVED RETARDANT PRODUCT.
- (i) STAND-ALONE FIRE DETECTORS SHALL BE PROVIDED IN ACCORDANCE WITH THE "STAND-ALONE FIRE DETECTOR GENERAL GUIDELINES ON PURCHASE, INSTALLATION & MAINTENANCE (SEP 2021)"; AND
(ii) IN RELATION TO (i) ABOVE, WHERE TWO OR MORE STAND-ALONE FIRE DETECTORS ARE INSTALLED IN AN ENCLOSED STRUCTURE, ALL DETECTORS SHALL BE INTERCONNECTED (EITHER WIRED OR WIRELESSLY) SUCH THAT WHEN ONE OF THE DETECTORS IS TRIGGERED, ALL CONNECTED DETECTORS SHALL SOUND AN ALARM SIMULTANEOUSLY.

B.D. Reference	
M.W. Reference	
L.D. Reference	
F.S.D. Reference	

Notes

Copyright Reserved nothing may be reprinted or utilized in any form or by any means without written permission from the M&D.

REV	DESCRIPTION	DATE

M&D
Planning and Construction
Consultants Ltd.

Tel: 2191 4008
Fax: 3105 0808
Email: sales@moderndesign.com.hk

Project

D.D.1TC, LOT 1386RP,
1387, 1395RP

Application
臨時商業及服務行業
(蔬菜及雜貨店)
連附寫字樓及貯物用途

Drawing Title

Scale	1:250 (A3)	Revisions	-
Designed by	LW	Drawn by	Arthur
Checked by	LW	Date	13-APR-2026
Job No.	-	Drawing No.	FS-01