

M.D. Reference	R. 204
M.W. Reference	101-143
L.D. Reference	401-127
F.S.D. Reference	401-127

Note
Copyright Reserved nothing may be reproduced or transmitted in any form or by any means without written permission from the M&D.

REV	DESCRIPTION	DATE

M&D
Planning and Construction
Consultants Ltd.
Tel: 2191 4288
Fax: 3105 0818
Email: sales@mmodem.com.hk

Project
D.D.1TC, LOT 1386RP,
1387, 1395RP

Application
臨時商業及服務行業
(雜貨及雜貨店)
連附屬寫字樓及貯物用途

Scale	1:250 (A3)	Revision	1
Designed by	LW	Drawn by	Arthur
Checked by	LW	Date	16-APR-2026
Job No.	1024	Drawing No.	FS-01

FIRE SERVICES NOTES
PORTABLE FIRE EXTINGUISHERS SHALL BE PROVIDED AS INDICATED ON THE BUILDING PLANS.

- STAND-ALONE FIRE DETECTORS SHALL BE PROVIDED IN ACCORDANCE WITH THE "STAND-ALONE FIRE DETECTOR GENERAL GUIDELINES ON PURCHASE, INSTALLATION & MAINTENANCE (SEP. 2021)"; AND
- IN RELATION TO (i) ABOVE, WHERE TWO OR MORE STAND-ALONE FIRE DETECTORS ARE INSTALLED IN AN ENCLOSED STRUCTURE, ALL DETECTORS SHALL BE INTERCONNECTED (EITHER WIRED OR WIRELESS) SUCH THAT WHEN ONE OF THE DETECTORS IS TRIGGERED, ALL CONNECTED DETECTORS SHALL SOUND AN ALARM SIMULTANEOUSLY.

營業時間: 星期一至五 08:00am-18:00pm (公眾假期照常營業)	14.88m ²
A 寫字樓 (6.1m x 2.4m x 2.0m高)	14.88m ²
B 員工休息室 (6.1m x 2.4m x 2.0m高)	3.78m ²
C 流動廁所 (0.1m x 1.8m x 不低於3m)	97.39m ²
E 雜貨貯存室 (3m高)	110.67m ²
F 雜貨零售區 (二層高風扇樓層3m高)	182.82m ²
G 散貨零售區 (二層高風扇樓層3m高)	共 695.48m ²

圖示:

- Cc 4.5公斤二氧化碳滅火器
- S_{Sa} 獨立火警偵測器
- 申請範圍

