

Attachment 3
Water Supply Impact Assessment

**Proposed Data Centre at No. 7-11 Wing
Kin Road, Kwai Chung (K.C.T.L. 145)**

**Water Supply Impact Assessment
(V1.0)**

May 2025

Approved By


(Project Manager: K.S. Lee)

REMARKS:

The information supplied and contained within this report is, to the best of our knowledge, correct at the time of printing.

CINOTECH accepts no responsibility for changes made to this report by third parties.

CINOTECH CONSULTANTS LIMITED

Room 1710, Technology Park

18 On Lai Street

Shatin, NT, Hong Kong

Tel: (852) 2151 2083 Fax: (852) 3107 1388

Email: info@cinotech.com.hk

TABLE OF CONTENTS

| | | |
|----------|---|----------|
| 1 | INTRODUCTION | 1 |
| 1.1 | BACKGROUND..... | 1 |
| 2 | DESCRIPTION OF THE ENVIRONMENT | 1 |
| 2.1 | EXISTING ENVIRONMENT..... | 1 |
| 2.2 | THE PROPOSED DEVELOPMENT..... | 1 |
| 3 | WATER SUPPLY IMPACT ASSESSMENT – FRESH WATER | 3 |
| 3.1 | EXISTING FRESH WATER SUPPLY | 3 |
| 3.2 | FRESH WATER DEMAND | 3 |
| 3.3 | FRESH WATER SUPPLY IMPACT - FRESH WATER SERVICE RESERVOIR | 4 |
| 3.4 | FRESH WATER SUPPLY IMPACT – FRESH WATER MAINS..... | 4 |
| 4 | WATER SUPPLY IMPACT ASSESSMENT – SALT WATER | 5 |
| 4.1 | EXISTING SALT WATER SUPPLY | 5 |
| 4.2 | SALTWATER SUPPLY DEMAND | 5 |
| 4.3 | SALTWATER SUPPLY IMPACT – SALT WATER PUMPING STATION..... | 6 |
| 4.4 | SALTWATER SUPPLY IMPACT – SALT WATER MAINS | 6 |
| 5 | CONSTRUCTION AND MAINTENANCE..... | 7 |
| 6 | CONCLUSION | 7 |

LIST OF TABLES

| | | |
|-----------|---|---|
| Table 2-1 | Development Parameters | 2 |
| Table 3-1 | Fresh Water Demand of the Existing Development | 3 |
| Table 3-2 | Fresh Water Demand of the Proposed Water Cooling Tower System | 3 |
| Table 3-3 | Fresh Water Demand of the Proposed Development..... | 4 |
| Table 3-4 | Summary of Fresh Water Demand | 4 |
| Table 4-1 | Salt Water Demand of the Existing Development | 5 |
| Table 4-2 | Salt Water Demand of the Proposed Development | 5 |
| Table 4-3 | Summary of Salt Water Demand | 6 |

LIST OF FIGURES

| | |
|------------|--|
| Figure 2-1 | Location of the Project Site |
| Figure 2-2 | Zoning in the Vicinity of the Project Site |
| Figure 3-1 | Fresh Water Mains in the Vicinity |
| Figure 3-2 | Proposed Modification of Fresh Water Mains |
| Figure 4-1 | Salt Water Mains in the Vicinity |

LIST OF APPENDICES

| | |
|--------------|-----------------------------------|
| Appendix I | Tentative Section Plan |
| Appendix II | Fresh Water Mains Record Plan |
| Appendix III | Salt Water Mains Record Plan |
| Appendix IV | Detailed Water Demand Calculation |

1 INTRODUCTION

1.1 Background

- 1.1.1 OXO YW Limited (“the Project Proponent”) has proposed to develop a data centre located at No. 7-11 Wing Kin Road, Kwai Chung.
- 1.1.2 Cinotech Consultants Limited was commissioned by OXO YW Limited to carry out a Water Supply Impact Assessment (WSIA) to assess and envisage any potential water supply impact on the implementation of the Project and to recommend improvement / modification works on the existing water supply system.

2 DESCRIPTION OF THE ENVIRONMENT

2.1 Existing Environment

- 2.1.1 The Application Site (the "Site") is located in an industrial area in Kwai Chung, bordered by Wing Chong Street to the west, Wing Kin Road to the east, Global Trade Centre to the north, and Hou Feng Industrial Building to the south (see **Figure 2-1**). The Site and its surroundings fall within the industrial zone, as per the *Approved Kwai Chung Outline Zoning Plan No. S/KC/32* (see **Figure 2-2**).
- 2.1.2 The Site covers approximately 964 m² (about 929 m² excluding the additional area) and is currently occupied by a 2-storey industrial building. Planning applications have been submitted and approved with conditions in 2020 (Application No.: A/KC/457) and 2023 (Application No.: A/KC/496) for Offensive Trades use (Lard Boiling Factory) and Industrial use (Warehouse), respectively.

2.2 The Proposed Development

- 2.2.1 The Project Proponent proposes to redevelop the Application Site into a 17-storey data centre with a height of 109.55 mPD and a plot ratio of 11.4. The tentative section plan of the proposed development is shown in **Appendix I**, with a planned completion date of 2029.
- 2.2.2 It should be noted that the proposed development is intended for Data Processing Centre use, and its water consumption behavior will differ significantly from typical industrial and commercial uses.
- 2.2.3 The major water consumption sources for the proposed development include:
- Water usage by staff
 - The proposed development is expected to be unmanned and automated, with a limited number of staff. As advised by the project applicant, up to 25 staff members will be employed.
 - Water consumption for the water cooling tower system

- A water cooling tower system will be implemented to meet the significant cooling demand, which will predominantly influence the fresh water requirements.
 - Irrigation of planters
- 2.2.4 On the other hand, no other water consumption activities within the proposed development are anticipated.
- 2.2.5 During operation, the bleed-off water from the water cooling tower system will be reused as much as practicable, with the expectation that all salt water demand for the proposed development will be met.

Development Parameters

- 2.2.6 This assessment is prepared based on the following development parameters (**Table 2-1**) of the notional design, which are subject to changes at detailed design stage:

Table 2-1 Development Parameters

| | Existing | Proposed Development |
|--------------------------------------|----------------------------|--------------------------------|
| Zoning | Industrial | |
| Site Area | About 964.2 m ² | |
| Use | Industrial | Data Processing Centre |
| Domestic GFA | 0 m ² | 0 m ² |
| Non-Domestic GFA (Industrial) | 941.21 m ² | About 10,991.88 m ² |
| Building Height | 60 mPD | 109.55 mPD |

Remarks: Development Parameters of the proposed development subject to detailed design.

3 WATER SUPPLY IMPACT ASSESSMENT – FRESH WATER

3.1 Existing Fresh Water Supply

- 3.1.1 The Application Site is currently served by the Lai Chi Kok Fresh Water Supply Reservoir (FWSR) (Capacity: 93,702 m³).
- 3.1.2 The Application Site is currently served by the 25 mm and 50 mm branches from the 300 mm fresh water main along Wing Kin Road, which originates from the 400 mm fresh water main along Kwai Hei Street.
- 3.1.3 The simplified fresh water mains records are illustrated in **Figures 3-1 and 3-2**. The Water Supplies Department (WSD) Fresh Water Mains Record Plan is provided in **Appendix II**.

3.2 Fresh Water Demand

- 3.2.1 The calculations of fresh water demand are generally following Departmental Instruction (DI) No. 1309 "Design Criteria," which adopted a per person or per GFA water consumption rate. The fresh water demand of the existing development is calculated in **Table 3-1** and detailed in **Table B of Appendix IV**.

Table 3-1 Fresh Water Demand of the Existing Development

| | Category | GFA (ha) | Unit Demand Fresh Water (m ³ /ha/day) | Daily Demand Fresh Water (m ³ /day) |
|------------------------|----------|----------|--|--|
| Industrial (Tsuen Wan) | I | 0.094 | 1600 | 150.594 |

- 3.2.2 As stated in **Section 2.2**, the water consumption behavior of the proposed development will differ significantly from typical industrial and commercial uses. Therefore, the water usage for staff, the water cooling tower system, and irrigation will be calculated separately, rather than using a GFA-based broad-brush estimation. Since the staff will not serve any customers, the water consumption figures for residents have been adopted. The fresh water demand of the proposed development is provided in **Table 3-2 & Table 3-3**, and detailed in **Tables C1 & C2 of Appendix IV**.

Table 3-2 Fresh Water Demand of the Proposed Water Cooling Tower System

| | | Unit | Remark |
|---|---------------|--------------------------|---|
| Designed Cooling load (Nominal) | 14 | MW | |
| Working Hour | 24 | hour/day | |
| Peak and Design Factor | 1.45 | | |
| Water evaporating rate under nominal load (with Peak and Design Factor) | 8.9942 | kg/s | Heat of vaporization for water is 2,257 kJ/kg |
| | 777.10 | m ³ /day | |
| Ratio of bleed-off water | 20% | % | A ratio 5:1 for evaporating : discharging has been adopted. |
| Amount of bleed-off water | 155.42 | m ³ /day | |
| Total water requirement | 932.52 | m³/day | |

Table 3-3 Fresh Water Demand of the Proposed Development

| | Category | Population or/ GFA (ha) | Unit Demand Fresh Water (m ³ /head/day) or (m ³ /ha/day) | Daily Demand Fresh Water (m ³ /day) |
|-------------------------------|----------|----------------------------|---|--|
| Staff | R | 25 (Population) | 0.35 | 8.750 |
| Water Cooling Tower system | N/A | N/A | N/A | 932.523 |
| Planter | IRR | 0.029 (GFA) [1] | 700 | 20.248 |

Noted:

[1] 30% of the Site area has been adopted for conservative assessment.

3.2.3 The fresh water demand for the site is expected to increase significantly from 150.594 m³/day to 961.521 m³/day, representing an increase of 810.927 m³/day (or 0.811 MLD). The calculations for fresh water demand in both existing and proposed scenarios are summarized in **Table 3-4**.

Table 3-4 Summary of Fresh Water Demand

| Daily Demand - Fresh Water (m ³ /day) | | |
|--|-----------------|---------------------|
| <i>Existing</i> | <i>Proposed</i> | <i>Net Increase</i> |
| 150.594 | 961.521 | 810.927 |

3.3 Fresh Water Supply Impact - Fresh water service reservoir

3.3.1 As shown in **Table D of Appendix IV**, there is substantially greater spare capacity (63.1 MLD) in Lai Chi Kok FWSR. The expected increase in demand (0.811 MLD) can therefore be accommodated by the existing Fresh Water Service Reservoirs. No adverse impact to the fresh water service reservoirs is anticipated.

3.4 Fresh Water Supply Impact – Fresh Water Mains

3.4.1 The Application Site is currently served by the 25 mm and 50 mm branches from the 300 mm fresh water main along Wing Kin Road, which originates from the 400 mm fresh water main along Kwai Hei Street as shown in **Figures 3-1 & 3-2**.

3.4.2 According to Departmental Instruction (DI) No. 1309 "Design Criteria," (DI 1309) the peak flow rate in the distribution mains for fresh water should be three times the daily demand. Based on this criterion, the estimated peak daily fresh water demand for the proposed development is approximately 2,884.6 m³/day. By following the maximum sustained flow velocity as suggested in DI 1309 (**Table A2 of Appendix IV**), the capacities of the 150 mm, 200 mm, 300 mm & 400 mm fresh water mains are determined to be 2,290 m³/day, 4,072 m³/day, 9,161 m³/day, & 21,715 m³/day respectively.

- 3.4.3 Taking into account the fresh water consumption of the proposed development, it has been determined that the existing 50 mm and 25 mm branches cannot meet the fresh water demand of the Site.
- 3.4.4 Therefore, a new 200 mm fresh water main connected to the existing 400 mm fresh water main along Kwai Hei Street has been proposed, as shown in **Figure 3-2**. Meanwhile, the existing 50 mm and 25 mm branches will be removed. The specific alignment and connection points of the proposed new water pipes will be determined during the detailed design phase of the development.

4 WATER SUPPLY IMPACT ASSESSMENT – SALT WATER

4.1 Existing Salt Water Supply

- 4.1.1 The Application Site is currently served by Tsuen Wan Salt Water Pumping Station (SWPS) (Design Pumping Capacity: 93 MLD).
- 4.1.2 The Application Site is currently served by a 25 mm branch from the 150 mm salt water main along Wing Kin Road.
- 4.1.3 The simplified salt water mains records are illustrated in **Figure 4-1**. The Water Supplies Department (WSD) Salt Water Mains Record Plan is provided in **Appendix III**, and detailed in **Table B of Appendix IV**.

4.2 Saltwater Supply Demand

- 4.2.1 The calculations of salt water demand are generally following Departmental Instruction (DI) No. 1309 "Design Criteria," which adopted a per person or per GFA water consumption rate. The fresh water demand of the existing development is calculated in **Table 3-4**.

Table 4-1 Salt Water Demand of the Existing Development

| | Category | GFA (ha) | Unit Demand Salt Water (m ³ /ha/day) | Daily Demand Salt Water (m ³ /day) |
|------------------------|----------|----------|---|---|
| Industrial (Tsuen Wan) | I | 0.094 | 210 | 19.765 |

- 4.2.2 Similar to the calculation of fresh water demand for the proposed development, the salt water consumption figures for residents have been adopted for staff. It should be noted that there is no salt water demand from the water cooling tower system or irrigation. The salt water demand of the proposed development is provided in **Table 4-2**, and detailed in **Table C2 of Appendix IV**.

Table 4-2 Salt Water Demand of the Proposed Development

| | Category | Population | Unit Demand Salt Water (m ³ /head/day) | Daily Demand Salt Water (m ³ /day) |
|-------|----------|------------|---|---|
| Staff | R | 25 | 0.110 | 2.750 |

- 4.2.3 The salt water demand for the site is expected to reduce from 19.765 m³/day to 2.750 m³/day, representing a decrease of 17.015 m³/day (or 0.017 MLD). The calculations for salt water demand in both existing and proposed scenarios are summarized in **Table 4-3**.

Table 4-3 Summary of Salt Water Demand

| Daily Demand - Salt Water (m ³ /day) | | |
|---|-----------------|---------------------|
| <i>Existing</i> | <i>Proposed</i> | <i>Net Increase</i> |
| 19.765 | 2.750 | -17.015 |

4.3 Saltwater Supply Impact – Salt Water Pumping Station

- 4.3.1 It should be noted that the existing daily consumption of the Tsuen Wan SWPS is close to its capacity. However, as shown in **Table 4-3**, the salt water demand is expected to decrease in the proposed development compared to the existing situation. Additionally, since the bleed-off water from the water cooling tower system will be reused as flushing water, no salt water demand is anticipated once the water reuse system of the cooling tower is properly implemented. No adverse impact to the salt water pumping station is anticipated.

4.4 Saltwater Supply Impact – Salt Water Mains

- 4.4.1 The Application Site is currently served by a 25 mm branch from the 150 mm salt water main along Wing Kin Road, as shown in **Figure 4-1**.
- 4.4.2 According to Departmental Instruction (DI) No. 1309 "Design Criteria," the peak flow rate in the distribution mains for salt water should be two times the daily demand. Based on this criterion, the estimated peak daily salt water demand for the proposed development is approximately 5.5 m³/day. By following the maximum sustained flow velocity as suggested in Departmental Instruction (DI) No. 1309 "Design Criteria" (**Table A2 of Appendix IV**), the capacities of the 25 mm and 150 mm salt water mains are determined to be 64 m³/day and 2,290 m³/day, respectively.
- 4.4.3 Taking into consideration the reduced salt water consumption of the proposed development, it has been determined that the existing 25 mm salt water main can meet the salt water demand of the Site, even when the water reuse system of the cooling tower is out of order. Therefore, no modifications to the salt water mains are required.


5 CONSTRUCTION AND MAINTENANCE

- 5.1.1 The detailed connection arrangements, responsibilities for the investigation, design, construction, repair and maintenance of the proposed modification to the fresh water mains system will be discussed among the Project Proponent and relevant Government departments in detailed design stage.


6 CONCLUSION

- 6.1.1 The potential water supply impact under the worst-case scenario of the proposed development has been reviewed. The assessment conducted concludes that no upgrading works on the water supply infrastructure will be required.
- 6.1.2 For the local water supply network, although the proposed development will result in additional fresh water demand, the increases can be accommodated by the existing main supply facilities and the proposed new pipes. Therefore, no adverse water supply impact is anticipated from the proposed development.


FIGURES




| | | | | |
|---------|-------------|-------------|----------|----------|
| SCALE | 1:1000 @ A3 | DATE | Jan 2025 | |
| CHECK | CC | DRAWN | LL | |
| JOB No. | IA23170 | DRAWING No. | 2-1 | REV - |




| | | | |
|---------|-------------|-------------|----------|
| SCALE | 1:1000 @ A3 | DATE | Jan 2025 |
| CHECK | CC | DRAWN | LL |
| JOB No. | IA23170 | DRAWING No. | 2-2 |
| | | REV | - |





APPENDIX I
TENTATIVE SECTION PLAN



ARCHITECT

STUDIO | RCM

18/F | Xiu Hua Commercial Building
211-213 Jaffe Road | Wan Chai | HK
Tel: 3583-2000 | Fax: 8143-1130
Email: mail@studiorcm.com

STUDIO | RAYMOND CHAU |
ARCHITECTURE | LIMITED

PROJECT NAME

PROPOSED DATA CENTRE
7-11 WING KIN ROAD
KWAI CHUNG, N.T.

DRAWING TITLE

SECTION A-A

| | |
|-----------------|---------------------|
| DRAWN BY TK | CHECKED BY RC |
| SCALE 1:750 | DATE 2025.06.18 |
| JOB No. 2208 | DRAWING No. A-14 |

APPENDIX II
FRESH WATER MAINS RECORD PLAN



- NOTES:
1. ALL DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE SPECIFIED.
 2. ALL LEVELS ARE IN METRES ABOVE PRINCIPAL DATUM.
 3. INFORMATION ON ALIGNMENT OF MAINS IS OF INDICATIVE VALUE ONLY WHERE POSITIONAL ACCURACY MAY BE OF IMPORTANCE. DETAILS SHOULD BE SITE CHECKED.
 4. FOR MAINS RECORDS SIGN CONVENTIONS AND DESIGNATIONS SEE SKETCH NO. 5988.
 5. NO PROPOSED WATER MAINS IN THE VICINITY OF THE SITE.
 6. NO EXISTING WSD CABLE IN THE VICINITY OF THE SITE.
 7. NO PROPOSED WSD CABLE IN THE VICINITY OF THE SITE.
 8. THE SITE IS NOT WITHIN WSD GATHERING GROUNDS.
 9. NO WSD LAND ALLOCATION WITHIN THE SITE AREA.
 10. NO WSD SLOPES ARE AFFECTED IN THE VICINITY OF THE SITE.
 11. ASBESTOS CEMENT, UNKNOWN MATERIALS MAINS WAS FOUND IN THE VICINITY OF THE SITE.
 12. NO CATHODIC PROTECTION MAINS ON THE VICINITY OF THE SITE.

PART COPY OF FRESH WATER MAINS RECORD PLAN(S)



W67880/7-SW-21A & 21C

FILE REF: A/KC/510

REF. CODE: 18W25M

SHEET 1 OF 1

SCALE 1:800



水務署
Water Supplies Department

APPENDIX III
SALT WATER MAINS RECORD PLAN



- NOTES:
1. ALL DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE SPECIFIED.
 2. ALL LEVELS ARE IN METRES ABOVE PRINCIPAL DATUM.
 3. INFORMATION ON ALIGNMENT OF MAINS IS OF INDICATIVE VALUE ONLY. WHERE POSITIONAL ACCURACY MAY BE OF IMPORTANCE, DETAILS SHOULD BE SITE CHECKED.
 4. FOR MAINS RECORDS SIGN CONVENTIONS AND DESIGNATIONS SEE SKETCH NO. 5988.
 5. NO PROPOSED WATER MAINS IN THE VICINITY OF THE SITE.
 6. NO EXISTING WSD CABLE IN THE VICINITY OF THE SITE.
 7. NO PROPOSED WSD CABLE IN THE VICINITY OF THE SITE.
 8. THE SITE IS NOT WITHIN WSD GATHERING GROUNDS.
 9. NO WSD LAND ALLOCATION WITHIN THE SITE AREA.
 10. NO WSD SLOPES ARE AFFECTED IN THE VICINITY OF THE SITE.
 11. ASBESTOS CEMENT, UNKNOWN MATERIALS MAINS WAS FOUND IN THE VICINITY OF THE SITE.
 12. NO CATHODIC PROTECTION MAINS ON THE VICINITY OF THE SITE.

PART COPY OF SALT WATER MAINS RECORD PLAN(S)



W67881/7-SW-21A & 21C

FILE REF: A/KC/510

REF. CODE: 18W25M

SHEET 1 OF 1

SCALE 1:800



水務署
Water Supplies Department

**APPENDIX IV
DETAILED WATER DEMAND
CALCULATION**

Table A1 - Unit Daily Demand

| Zone Type | | Unit Demand Fresh Water ^[1] | Unit Demand Salt Water ^[2] | (unit) |
|------------------------|-----|---|--|--------------------------|
| Staff | R | 0.35 | 0.11 | m ³ /head/day |
| Industrial (Tsuen Wan) | I | 1600 | 210 | m ³ /ha/day |
| Planter (Irrigation) | IRR | 700 | 0 | m ³ /ha/day |

[1] Unit Demand Fresh Water:

- Residential - 0.35 m³/head/day, including service trade allowance, has been adopted for Staff.
- Industrial (Tsuen Wan) - 1600 m³/ha/day.
- Irrigation Area - 70 litre / sq. meters of irrigation area / day.

[2] Unit Demand Salt Water:

- Residential - 0.11 m³/head/day, including service trade allowance, has been adopted for Staff.
- Industrial (Tsuen Wan) - 210 m³/ha/day.

Table A2 - Flow Velocity Limit

| Pipe Diameter | Fresh Water Distribution Mains | (unit) |
|---------------|--------------------------------|--------|
| > DN700 | ≤ 3 | m/s |
| DN700 - DN525 | ≤ 2.5 | m/s |
| DN450 - DN375 | ≤ 2 | m/s |
| DN300 - DN200 | ≤ 1.5 | m/s |
| < DN200 | ≤ 1.5 | m/s |
| Pipe Diameter | Salt Water Distribution Mains | (unit) |
| ≥ DN1000 | ≤ 3.0 | m/s |
| DN900 - DN800 | ≤ 2.5 | m/s |
| DN700 - DN525 | ≤ 2 | m/s |
| DN450 - DN300 | ≤ 1.5 | m/s |
| < DN300 | ≤ 1.5 | m/s |

[1] Refer to *WSD Departmental Instruction 1309*

Table B - Existing Water Demands

Non-Residential Area

| | Category | GFA (ha) | Unit Demand Fresh Water (m ³ /ha/day) | Unit Demand Salt Water (m ³ /ha/day) | Daily Demand Fresh Water (m ³ /day) | Daily Demand Salt Water (m ³ /day) |
|----------------------------|----------|----------|--|---|--|---|
| Industrial (Tsuen Wan) (I) | I | 0.094 | 1600.000 | 210.000 | 150.594 | 19.765 |

Summary

| | Daily Demand Fresh Water (m ³ /day) | Daily Demand Salt Water (m ³ /day) |
|---------------------|--|---|
| <u>Total</u> | 150.594 | 19.765 |

Table C1 - Water Demands of Water Cooling Tower System

| | | Unit | Remark |
|---|---------------|---------------------|--------|
| Designed Cooling load (Nominal) | 14 | MW | |
| Working hour | 24 | hour/day | |
| Peak and Design Factor | 1.45 | | |
| Water evaporating rate under nominal load (with Peak and Design Factor) | 8.9942 | kg/s | [1] |
| | 777.10 | m ³ /day | |
| Ratio of bleed-off water | 20% | | [2] |
| Amount of bleed-off water | 155.42 | m ³ /day | |
| | | | |
| Total water requirement | 932.52 | m ³ /day | |

[1] Heat of vaporization for water is 2257 kJ/Kg

[2] A ratio 5:1 for evaporating: discharging has been adopted.

Table C2 - Proposed Water Demands

Staff

| | Category | Population | Unit Demand Fresh Water (m ³ /head/day) | Unit Demand Salt Water (m ³ /head/day) | Daily Demand Fresh Water (m ³ /day) | Daily Demand Salt Water (m ³ /day) |
|-------|----------|------------|---|--|---|--|
| Staff | R | 25 | 0.350 | 0.110 | 8.750 | 2.750 |

Water Cooling Tower System

| | Category | GFA (ha) | Unit Demand Fresh Water (m ³ /ha/day) | Unit Demand Salt Water (m ³ /ha/day) | Daily Demand Fresh Water (m ³ /day) | Daily Demand Salt Water (m ³ /day) |
|----------------------------|----------|----------|--|---|---|--|
| Water Cooling Tower System | N/A | N/A | N/A | N/A | 932.523 | 0.0 |

Public Open Space

| | Category | Area (ha) ^[1] | Unit Demand Fresh Water (m ³ /ha/day) | Unit Demand Salt Water (m ³ /ha/day) | Daily Demand Fresh Water (m ³ /day) | Daily Demand Salt Water (m ³ /day) |
|---------------|----------|--------------------------|--|---|---|--|
| Planter (IRR) | IRR | 0.029 | 700.000 | 0.000 | 20.248 | 0.0 |

Summary [3]

| | Daily Demand Fresh Water (m ³ /day) | Daily Demand Salt Water (m ³ /day) |
|---------------------|---|---|
| <u>Total</u> | 961.521 | 2.750 |

Note:

[1] 30% of the Site area has been adopted for conservative assessment.

Table D - Summary of Water Demands

Fresh Water Demand

| | Daily Demand - Fresh Water (m ³ /d) | | |
|--------------|--|----------------|----------------|
| | Existing | Proposed | Net Increase |
| Total | 150.594 | 961.521 | 810.927 |

Salt Water Demand

| | Daily Demand - Salt Water (m ³ /d) | | |
|--------------|---|--------------|----------------|
| | Existing | Proposed | Net Increase |
| Total | 19.765 | 2.750 | -17.015 |

Fresh Water Reservoir Capacity

| Reservoir | Capacity (x 1,000 m ³) | Supply Capacity @ Capacity Factor = 0.8 (MLD) ^[1] | Existing Daily Consumption (MLD) ^[2] | Spare Capacity (MLD) | Remarks |
|------------------|---------------------------------------|--|--|-------------------------|--|
| Lai Chi Kok FWSR | 93.702 | 117.13 | 54 | 63.1 | The spare capacity of 63.1 MLD >> net increase of 0.8 MLD from the |

Salt Water Pumping Capacity

| Pumping Station | Design Pumping Capacity (MLD) | Existing Daily Consumption (MLD) ^[2] | Spare Capacity (MLD) | Remarks |
|-----------------|-------------------------------|--|-------------------------|---|
| Tsuen Wan SWPS | 93.0 | 93.0 | 0.0 | The salt water demand of the Proposed Development will be reduced |

[1] For interconnected supply zone with critical consumers, the capacity of the Reservoir should be (75% + 5%) = 80% of the mean daily demand.

[2] Average daily Consumptions provided by WSD in May 2025.