

**Application under Section 16 of the Town Planning Ordinance
Proposed Minor Relaxation of Plot Ratio and Building Height Restrictions
for Permitted Information Technology and Telecommunications Industries (Data Processing Centre)
at 7-11 Wing Kin Road, Kwai Chung, New Territories
in DD 446, Kwai Chung Town Lot 145 and adjoining Government Land
at Wing Chong Street (Application No. A/KC/510)**

Departmental Comments (Further Information (F.1.)(4))	Response to Comments
<p><u>Comments by Environmental Protection Department (10.9.2025)</u></p> <p><i>Revised Air Quality Impact Assessment (AQIA)</i></p> <p>1. Section 2.2.4: To ensure consistency with other sections (e.g. S.2.2.5, S.6.1.2, S.6.4.1, etc.), please update this section as: “Routine testing of the each backup generators will be conducted for 30 minutes monthly each month, resulting in an annual operation time of 6 hours for each backup generator. The each backup generators will be tested one at a time sequentially to minimize emissions rates.”</p>	<p>Section 2.2.4 has been revised accordingly.</p>
<p>2. The Applicant should ensure consistency of information in the AQIA.</p>	<p>Noted. We have checked and can confirm the consistency in the report.</p>

Enclosures

1. **Attachment 1** – Replacement Section 2.2.4 of the AQIA Report

