圖示:		LEGEND	PROPOSED USE	COVERED AREA	NO. OF STOREYS	BUILDING HEIGHT
	緊急照明燈	(A) (B) (C)	WAREHOUSE AREA WAREHOUSE AREA OFFICE & MALE/FEMALE LAVATORY	631.60m ² (ABOU ² 226.32m ² (ABOU ² 21m ² (ABOU ²	r)́ 1	6m (ABOUT) 6m (ABOUT) 3m (ABOUT)
$\mathbb{C}_{\mathbb{C}}$	4.5公斤二氧化碳滅火器	(D) (E)	OFFICE & MALE/FEMALE LAVATORY TRAFFIC WARDEN RM.&METER RM	15m ² (ABOU ⁻ 14m ² (ABOU ⁻	r)́ 1	3m (ABOUT) 3m (ABOUT) 3m (ABOUT)
$\overline{\otimes}$	緊急出路指示牌		STORE ROOM (2.35x5.9x2)	27.8m² (ABO	UT) 1	2.6m (ABOUT)
	申請範圍					



M.W. Reference	小型工程檔案
L.D. Reference	地政署檔案
F.S.D. Reference	液的疾症等

Notes


B.D. Reference

Copyright Reserved nothing may be reprinted or utilized in any form or by any means without written permission from the M&D.

DESCRIPTION

REV

DATE



FIRE SERVICES NOTES

- PORTABLE FIRE EXTINGUISHERS SHALL BE PROVIDED AS INDICATED ON THE BUILDING PLANS.
- 2. ALL LININGS FOR ACOUSTIC, THERMAL INSULATION PURPOSES IN DUCTINGS AND CONCEALED LOCATIONS SHALL BE OF CLASS 1 OR CLASS 2 RATE OF SURFACE SPREAD OF FLAME AS PER BRITISH STANDARD 476: PART 7 OR ITS INTERNATIONAL EQUIVALENT, OR BE BROUGHT UP TO THAT STANDARD BY USE OF AN APPROVED FIRE RETARDANT PRODUCT.
- ANY INTENDED STORAGE OR USE OF DANGEROUS GOODS AS DEFINED IN CHAPTER 295 OF THE LAWS OF HONG KONG SHOULD BE NOTIFIED TO THE DIRECTOR OF FIRE SERVICES.
- 4. EMERGENCY LIGHTING SHALL BE PROVIDED THROUGHOUT THE ENTRE BUILDING AND ALL EXIT ROUTES LEADING TO GROUND LEVEL AND COMPLIED WITH BS 5266 PART 1:2016 AND BS EN 1838:2013 AND FSD CIRCULAR LETTER 4/2021
- 5. SECONDARY POWER SUPPLY TO BE CONNECTED BEFORE BUILDING'S MAIN SWITCH.
- 6. EXIT SIGN SHALL BE PROVIDED AND COMPLIED WITH BS5266 PART 1:2011 & FSD C.L 5/08



LOTS 200, 203R.P., 204, 225S.A., 225R.P., 226R.P., 227RP AND 216 AND ADJOINING GOVERNMENT LAND IN D.D.52, FU TEI AU, SHEUNG SHUI, NEW TERRITORIES

Application
TEMPORARY PLANNING APPLICATION
TO PROPOSED TEMPORARY CARGO
HANDLING AND FORWARDING
FACILITY USE AND ASSOCIATED
FILLING OF LAND
FOR A PERIOD OF 3 YEARS

PROPOSED F.S. LAYOUT PLAN

Scale		比例	Revisions	修定
1:500 (A3)		_		
Designed by	十者	Drawn	by	制鋼人
LW		Arthur		
Checked by 檢查	Da	te		日期
LW	15-AUG-2025			
Job No. 工程項目	Dro	wing N	lo.	圆號
_	FS-01			