
DEVELOPMENT PARAMETERS

APPLICATION SITE AREA	: 1,574 m^2 (ABOUT)
COVERED AREA	: NOT APPLICABLE
UNCOVERED AREA	: 1,574 m^2 (ABOUT)
OPEN STORAGE AREA	: 997 m^2 (ABOUT)
HEIGHT OF STACKING	: NOT MORE THAN 3 m

NO STRUCTURE IS PROVIDED AT THE APPLICATION SITE



FIRE SERVICE INSTALLATIONS

FE DP 4 KG DRY POWDER TYPE FIRE EXTINGUISHER

FS NOTES:

1) A SUITABLE TYPE OF PORTABLE FIRE EXTINGUISHER SHALL BE PROVIDED IN LOCATIONS WHERE EASILY ACCESSIBLE BY PERSON IN CHARGE WHERE THE NO. OF F.E. SHALL BE PROVIDED ACCORDING TO THE FORMULA = [STORAGE AREA](m²) X [0.003]

2) PORTABLE HAND-OPERATED APPROVED APPLIANCE SHALL BE PROVIDED AS REQUIRED BY OCCUPANCY.

3) ACCESS IS PROVIDED FOR EMERGENCY VEHICLE TO REACH 30m OF ALL PART OF STRUCTURES.

PARKING AND LOADING / UNLOADING PROVISIONS

NO. OF L/UL SPACE FOR LIGHT GOODS VEHICLE	: 1
DIMENSION OF L/UL SPACE	: 7 m (L) x 3.5 m (W)
NO. OF L/UL SPACE FOR MEDIUM GOODS VEHICLE	: 1
DIMENSION OF L/UL SPACE	: 11 m (L) x 3.5 m (W)

LEGEND

- APPLICATION SITE
- OPEN STORAGE AREA
- LOADING/UNLOADING SPACE (LGV)
- LOADING/UNLOADING SPACE (MGV)
- INGRESS / EGRESS

NORTH
W E
S

PROJECT
PROPOSED TEMPORARY OPEN STORAGE OF CONSTRUCTION MATERIALS AND MACHINERY FOR A PERIOD OF 3 YEARS

PROJECT
LOT 141 RP (PART) IN D.D. 52, FU TEI AU, SHEUNG SHUI, NEW TERRITORIES

PROJECT TITLE	*FIRE SERVICE INSTALLATIONS PROPOSAL*
SCALE	*1 : 500 @ A4*
DRAWN BY	*LT*
DATE	*02.10.2026*
DWG NO.	*APPENDIX I*
VER.	*VERSION 1*