



Note:

- Catchpits (CP11) with desilting facility shall follow CEDD standard drawing No. C2406I.
- Catchpit and UC follows Typical Details of Geotechnical Manual for Slope Fig.8.10 and Fig.8.11 respectively.
- Open-bottom type fence wall to be erected.
- No site formation/ filling works to be carried out.



LEGEND

- CP Proposed CatchPit
- (a) Proposed 525UC (1:175) with Cast Iron Cover
- (b) Proposed 750mm dia. concrete pipe (1:150)
- Existing 1.5m(W)x1.2m(D) Open Channel



CONNECTION DETAILS

正宏工程顧問公司

CHING WAN ENGINEERING CONSULTANT COMPANY

Project:

Lot 501 and various lots in D.D. 80 , Hung Lung Hang, Ta Kwu Ling, New Territories

(Application No.:)

Title:

Drainage Proposal - LAYOUT

D01

Drawn by:

DM


Date:

24-7-2025

Check by:

DM

Scale:



正宏工程顧問公司

CHING WAN ENGINEERING CONSULTANT COMPANY

Project:
Lot 501 and various lots in D.D. 80 , Hung Lung Hang, Ta Kwu Ling, New Territories

(Application No.:)

Title:

Drainage Proposal -
CATCHMENT AREA PLAN

D02

Drawn by:

DM


Date:

24-7-2025

Check by:

DM

Scale:



THS SITE

<div>正宏工程顧問公司</div> <div>CHING WAN ENGINEERING CONSULTANT COMPANY</div> <div>Project: Lot 501 and various lots in D.D. 80 , Hung Lung Hang, Ta Kwu Ling, New Territories</div> <div>(Application No.:)</div>	Title: Drainage Proposal - SECTIONS		D03
	Drawn by: DM	Date: 24-7-2025	
	Check by: DM	Scale: ----	

Outside Catchment Area, Area = 8533 m² (C= 0.25)
 THE SITE, Area = 12922 m² (C= 0.95)

Calculation of Design Runoff of the Proposed Development,

For the design of drains inside of the site, Catchment Area + The Site/2

$$\Sigma Q = \Sigma 0.278 C i A$$

$$\begin{aligned} A &= 8533/2 + 12922/2 \quad \text{m}^2 \\ &= 10727.5 \\ &= 0.0107275 \quad \text{km}^2 \end{aligned}$$

$$\begin{aligned} t &= 0.14465 L / H^{0.2} A^{0.1} \\ &= 0.14465 * 176 / 1^{0.2} * 10727.5^{0.1} \\ &= 10.064 \quad \text{min} \end{aligned}$$

$$\begin{aligned} i &= 1.111 * a / (t + b)^c \quad (50 \text{ yrs return period, Table 3a, Corrigendum 2024,} \\ &= 1.111 * 505.5 / (10.064 + 3.29)^{0.355} \quad \text{SDM) and (11.1\% increase due to climate change)} \\ &= 223.8 \quad \text{mm/hr} \end{aligned}$$

$$\begin{aligned} \text{Therefore, } Q &= 0.278 * 0.25 * 223.8 * 0.0042665 + 0.278 * 0.95 * 223.8 * 0.006461 \\ &= 0.4482 \quad \text{m}^3/\text{sec} \\ &= \underline{26893} \quad \text{lit/min} \end{aligned}$$

Provide 525UC (1:175) is OK

For Outfall


$$\begin{aligned} \text{Therefore, } Q &= 0.4482 * 2 \\ &= 0.8964 \quad \text{m}^3/\text{sec} \\ &= \underline{53787} \quad \text{lit/min} \end{aligned}$$

Provide 750mm dia concrete pipe (1:150) is OK (refer to next page)

GEO Technical Guidance Note No. 43 (TGN 43)
Guidelines on Hydraulic Design of U-shaped and Half-round Channels on Slopes

Issue No.: 1	Revision: -	Date: 05.06.2014	Page: 3 of 3
--------------	-------------	------------------	--------------

Figure 1 - Chart for the rapid design of U-shaped and half-round channels up to 600 mm



Check 750mm dia. Pipes by Colebrook-White Equation


$$V = -\sqrt{(8gDs)} \log\left(\frac{ks}{3.7D} + \frac{2.51v}{D\sqrt{(2gDs)}}\right)$$

where :


V	=		mean velocity (m/s)	
g	=	9.81	m/s ² gravitational acceleration (m/s ²)	
D	=	0.75	m internal pipe diameter (m)	
ks	=	0.00015	m hydraulic pipeline roughness (m)	(Table14, from DSD SDM 2018, concrete pipe)
v	=	1.14E-06	m ² /s kinematic viscosity of fluid (m ² /s)	
s	=	0.006667	hydraulic gradient	(1: 150)

Therefore, design V of pipe capacity = 2.62 m/s

Q= 0.8VA		(0.8 factor for sedimentation)
= 0.925	m ³ /s	
= 55511	lit/min	
> 53787	lit/min	Ok




NOMINAL SIZE (LARGEST OF H1, H2, H3 & H4)	B
300 - 600	150
675 - 900	175




NOTES:

1. ALL DIMENSIONS ARE IN MILLIMETRES.
2. REFER TO SHEET 2 FOR OTHER NOTES.

CATCHPIT WITH TRAP
(SHEET 1 OF 2)

-	FORMER DRG. NO. C2406J.	Original Signed	03.2015
REF.	REVISION	SIGNATURE	DATE
 CIVIL ENGINEERING AND DEVELOPMENT DEPARTMENT		SCALE 1 : 20 DATE JAN 1991	
		DRAWING NO. C2406 /1	



ALTERNATIVE TOP SECTION FOR PRECAST CONCRETE COVERS / GRATINGS

NOTES:

1. ALL DIMENSIONS ARE IN MILLIMETRES.
2. ALL CONCRETE SHALL BE GRADE 20 /20.
3. CONCRETE SURFACE FINISH SHALL BE CLASS U2 OR F2 AS APPROPRIATE.
4. FOR DETAILS OF JOINT, REFER TO STD. DRG. NO. C2413.
5. CONCRETE TO BE COLOURED AS SPECIFIED.
6. UNLESS REQUESTED BY THE MAINTENANCE PARTY AND AS DIRECTED BY THE ENGINEER, CATCHPIT WITH TRAP IS NORMALLY NOT PREFERRED DUE TO PONDING PROBLEM.
7. UPON THE REQUEST FROM MAINTENANCE PARTY, DRAIN PIPES AT CATCHPIT BASE CAN BE USED BUT THIS IS FOR CATCHPITS LOCATED AT SLOPE TOE ONLY AND AS DIRECTED BY THE ENGINEER.
8. FOR CATCHPITS CONSTRUCTED ON OR ADJACENT TO A FOOTPATH, STEEL GRATINGS (SEE DETAIL 'A' ON STD. DRG. NO. C2405 /2) OR CONCRETE COVERS (SEE STD. DRG. NO. C2407) SHALL BE PROVIDED AS DIRECTED BY THE ENGINEER.
9. IF INSTRUCTED BY THE ENGINEER, HANDRAILING (SEE DETAIL 'J' ON STD. DRG. NO. C2405 /5; EXCEPT ON THE UPSLOPE SIDE) IN LIEU OF STEEL GRATINGS OR CONCRETE COVERS CAN BE ACCEPTED AS AN ALTERNATIVE SAFETY MEASURE FOR CATCHPITS NOT ON A FOOTPATH NOR ADJACENT TO IT. TOP OF THE HANDRAILING SHALL BE 1 000 mm MIN. MEASURED FROM THE ADJACENT GROUND LEVEL.
10. MINIMUM INTERNAL CATCHPIT WIDTH SHALL BE 1 000 mm FOR CATCHPITS WITH A HEIGHT EXCEEDING 1 000 mm MEASURED FROM THE INVERT LEVEL TO THE ADJACENT GROUND LEVEL. AND, STEP IRONS (SEE DSD STD. DRG. NO. DS1043) AT 300 c/c STAGGERED SHALL BE PROVIDED. THICKNESS OF CATCHPIT WALL FOR INSTALLATION OF STEP IRONS SHALL BE INCREASED TO 150 mm.
11. FOR RETROFITTING AN EXISTING CATCHPIT WITH STEEL GRATING, SEE DETAIL 'G' ON STD. DRG. NO. C2405 /4.
12. SUBJECT TO THE APPROVAL OF THE ENGINEER, OTHER MATERIALS CAN ALSO BE USED AS COVERS / GRATINGS.

A	MINOR AMENDMENT.	Original Signed	04.2016
-	FORMER DRG. NO. C2406J.	Original Signed	03.2015
REF.	REVISION	SIGNATURE	DATE

**CATCHPIT WITH TRAP
(SHEET 2 OF 2)**



**CIVIL ENGINEERING AND
DEVELOPMENT DEPARTMENT**

SCALE 1 : 20


DATE JAN 1991

DRAWING NO.

C2406 /2A



Figure 8.10 - Typical Details of Catchpits



Dimensions of U - channel

Nominal size of channel H (mm)	Thickness t (mm)	Thickness b (mm)
225 to 600	150	150
675 to 1200	175	225

Figure 8.11 - Typical U-channel Details