

☐Urgent ☐Return receipt ☐Expand Group ☐Restricted ☐Prevent Copy

Adrian Tsz Hin TAM/PLAND

寄件者: INNOVATIVE LAND USE PLANNING <[REDACTED]>
寄件日期: 2026年09月14日星期一 18:42
收件者: Adrian Tsz Hin TAM/PLAND
副本: Sheren Si Wai LEE/PLAND; Johnny Chung Yin LAM/PLAND
主旨: Re: Planning Application No. A/NE-TKL/850 --- Proposed Temporary Warehouse for Storage of Construction Materials/Tools and Equipment with Ancillary Office/Workshop and Associated Filling of Land for a Period of 3 Years

類別: Internet Email

Dear Adrian,

Please find our responses to TD's comments as follow:

1. The width of the ingress and egress is 6.2m wide,
2. Install warning signs (yellow/black) written "Caution: Vehicles entering and Exiting" and install convex mirrors to alert both pedestrians and vehicle users.
3. Erect a signage "Do not block the passageway" at the ingress and egress area.
4. Erect a signage " No parking" at the ingress and egress area.
5. The applicant will seek approvals from the concerned land owners for the entry of vehicles between Ping Che Road and the application site.

Elaine SO

Town Planner

Innovative Land Use Planning Consultancy Co Ltd