

☐Urgent ☐Return receipt ☐Expand Group ☐Restricted ☐Prevent Copy ☐Confidential


Sheren Si Wai LEE/PLAND

寄件者: [REDACTED]
寄件日期: 2025年08月07日星期四 17:07
收件者: Sheren Si Wai LEE/PLAND
主旨: RE: Application No. A/NE-WKS/21 - Proposed Temporary Public Utility Installation (Solar Photovoltaic System) for a Period of 5 Years

類別: Internet Email

Dear Sheren Lee


- 1) How is the existing condition of the subject site? Has any land filling works taken place?
The current condition of the land is mud, but artificial turf is laid, and it can be restored to its original state at any time if it needs to be recultivated.
- 2) Will any filling/excavation of land be needed underneath the footings of the solar panels?



No excavation and filling works are required

- 3) How tall are the supporting frames of the solar panels?

☐Urgent ☐Return receipt ☐Expand Group ☐Restricted ☐Prevent Copy ☐Confidential



The height of the supporting frame is 1.554M

Regards

Leo Wong