

☐Urgent ☐Return receipt ☐Expand Group ☐Restricted ☐Prevent Copy

Gordon Tsz Chung CHENG/PLAND

寄件者: [REDACTED]
寄件日期: 2026年09月03日星期四 14:34
收件者: [REDACTED]
主旨: Application No. A/SK-HC/376 - Proposed House (New Territories Exempted House (NTEH) - Small House) at Lot 546 S.D, 548 S.A and 549 S.A in D.D. 244, Ho Chung, Sai Kung

類別: Further Information/Supplementary Information, Internet Email

Dear Mr Cheng / Mr. Yip

Application No. A/SK-HC/376 - Proposed House (New Territories Exempted House (NTEH) - Small House) at Lot 546 S.D, 548 S.A and 549 S.A in D.D. 244, Ho Chung, Sai Kung

I refer to the DSD comment on your email dated 27/07/2026 of the captioned subject.

I would like to advise that the septic tank and soakaway pit are to be located on western side of the application house near corner A, with sizes of 2.5m(L) x 1.25m(W) and 1.25m(L) x 1.25m(W).

Your faithfully,

Danube Lo

[REDACTED]