



Pole stay 5m high above ground

		REVS.	A	B	C	D	E	F	G	H	J	K	L
		INITIAL											
DRAWN: T.W.L.		TITLE: 11kV OHL WOOD POLE SPECIFICATION GENERAL ARRANGEMENT OF STAYS (SHEET 1)											
CHECKED: W.M.CHANG		PROJECT NO.											
DATE: 6-2-03		CONTRACT NO.											
APPROVED: W.M.CHANG		DRG. NO. T GEN 51220 DE33013801-A											
SCALE: N.T.S.		SHEET(S) IN SET: 1											
ASSET MANAGEMENT		INFORMATION CLASS: PROPRIETARY ALL RIGHTS RESERVED AND REPRODUCTION IN ANY FORM MUST BE APPROVED BY CLP POWER											

Excavation for pole stay:
1m(Length)x1m(Width)x1.2m(Depth)
Item 3,4,6,7,9,10,11,13,14,15