序號 Serial Number

A 9953425

FIRE SERVICE (INSTALLATIONS AND EQUIPMENT) REGULATIONS FSD Ref. (REGULATION 9(1)) CERTIFICATE OF FIRE SERVICE INSTALLATION AND EQUIPMENT 顧客姓名 冠來有限公司 Name of Client 樓宇名稱 屋邨/鄉村名稱 Name of Estate/Village 樓字地址 Yuen Shun Circuit, Yuen Chau Kok Koon Wah Building Name of Building Address of Block Building 門牌號數及街道/地段 地區 Shatin Number and 2 District Name of Street/Lot 持牌/註冊處所類型 ☐ 簡樸房 Basic Housing Unit (如適用) ☐ 危險品倉 Dangerous Goods Store 危險品車輛 Dangerous Good Vehicle 木料倉 Timber Store Registered Premises □食物業處所 Food Premises ■電器廢物處置 E-waste Disposal 公眾娛樂場所 Place of Public Entertainment (If applicable) 校舍 School Premises □改建校舍 Non-designed School 安老院舍 Residential Care Home for the Elderly 請在合適空格內填 上「✓」號 Please tick the ■私營骨灰安置所 Private Columbaria □幼兒中心 Child Care Centre 殘疾院舍 Residential Care Home for Persons with Disabilities 卡拉 OK 場所 Karaoke Establishment ☐賓館 Guesthouse ■ 酒店 Hotel appropriate "box" ☐ 會社 Club □床位寓所 Bedspace Apartment 根據《消防(裝置及設備)規例》第八條(1)(b)款,擁有裝置在任何處所內的任何消防裝置或設備的人,須每 12 個月由一名註冊承辦商檢查該等消防裝置或設備至少一次。 In accordance with Regulation 8(1)(b) of Fire Service (Installations and Equipment) Regulations, the owner of any fire 第一部 只適用於年檢事項 Part 1 Annual Inspection ONLY service installation or equipment which is installed in any premises shall have such fire service installation or equipment inspected by a registered contractor at least once in every 12 months. 到期日 編碼 狀況評述 裝置類型 位置 Due Date Completion Date Code Type of FSI Location(s) Comment on Condition (DD/MM/YYYY) (DD/MM/YYYY) (1-35)20/11/2026 12 Exit Sign Whole Building Conforms with FSD requirements 21/11/2025 21/11/2025 20/11/2026 13 Fire Alarm System (MFA) Whole Building Conforms with FSD requirements 20/11/2026 16 Fire Hydrant / Hose Reel Whole Building Conforms with FSD requirements 21/11/2025 System 28 Sprinkler System Whole Building Conforms with FSD requirements 21/11/2025 20/11/2026 部 Part 2 裝置/保養/修理/檢查工作 Installation/Maintenance/Repair/Inspection work 第 消防裝置關閉/嚴重損壞/恢復通知書 完成之工作内容 Nature of Work 完成日期 編碼 狀況評述 消防處檔案編號 FSD serial number of Notification of 裝置類型 位置 Completion Date Code Comment on Condition Type of FSI Location(s) (1-35)Carried out (DD/MM/YYYY) FSI Shutdown/Major Defect/Resumption < NIL -Varian 4 less 第三部 Part 3 欠妥事項 Defects 欠妥事項 消防裝置關閉/嚴重損壞/恢復通知書 編碼 Defects 消防處檔案编號
FSD serial number of Notification of
FSI Shutdown/Major Defect/Resumption 位置 欠妥事項評述 裝置類型 (請以「*」註明主要系統嚴重損壞 Please indicate major defects in major system with a *** sign) Code Type of FSI Location(s) Comment on Defects (1-35)- NII faint Main System will Freed Pulpis) 本人/我們藉此聲明,上述之消防裝置/設備經測試及/或檢查,其連作狀況符合消防處應長訂明適用於該 建築物/應所的《最低限度之消防裝置及設備守則》中的規格/要求,以及最新的《裝置及設備之檢查、 測試及保養守則》中的要求,以證明其性能良好,除在第三部分中詳列的裝置/設備欠妥事項(如有)。 註冊編號 RC1/512, RC2/684 Registration No. I/We hereby declare that the above installations/equipment has/have been tested and/or inspected, with its/their working conditions certified in conformance with the specifications/requirements in the Code of Practice for Minimum Fire Service Installations and Equipment applicable to the building/premises and the requirements in the latest Code of Practice for Inspection, Testing and Maintenance of Installations and Equipment prescribed by the Director of Fire Services to be in efficient working order except defect(s) of the installations/equipment, if any, detailed in Part 3. 註冊消防裝置承辦商名稱 Global Engineering Name of Registered Fire Service Installation Contractor Consultants Limited 聯絡電話 3188 1924 Telephone 請將此證書張貼於大廈或處所當眼處以供消防處人員查核 Please display this certificate at a conspicuous place in the building or premises for FSD's inspection. 電郵地址 globalconhk@gmail.com Email address 日期 獲授權簽署人簽署 21/11/2025 Date Signature of Authorized Signatory 備註 獲授權簽署人姓名 Chiu Tsz Wai Remark Name of Authorized Signatory

消防(裝置及設備)規例

用的(袋鱼及畝桶) (Regulation 9(1)) A9707450

FSD Ref.: 消防處檔號

F.S. 251 (Rev. 1/2016)

(第九條(1)款) CERTIFICATE OF FIRE SERVICE INSTALLATION AND EQUIPMENT

				消防裝置	星及設備證書	(April 1971) 15 15 15 15 15 15 15 15 15 15 15 15 15	
Name of 顧客姓	f Client: 名	冠來有	限公司	yaq W n	ليتنس تخاني الس	سمستر الرجا المش	
Vame of 婁宇名	f Building : 稱	Koon W	ah Building	liit (it isii	VIV promo nootal!	olomi Biaxe Carlanzo	=1
Street No./Town Lot: 門牌號數/市地段 Block: 座			2 District 分區		ad/Estate Name: /屋苑名稱	Yuen Shun Circuit, Yuen Chau Kok	
					Shaun	Area: HK K NT 地區 香港 九龍 A新界	
Pa	Building 樓字 rt 1 Annual In 一部 只適	nspection C	NLY In acception once in acception once in acception once in acceptance	cordance with Regulat ment which is installed in every 12 months.	ion 8(b) of Fire Service (Installation	site等合 Licensed premise in and Equipment) Regulations, the own service installation or equipment inspecte 八條(b)款,擁有裝置在任何處所內 備至少一次。	er of any fire service installation o
Code編碼	Type of FSI		Location(s) 位置		n Condition 狀況評述	Completion Date 完成日期(DD/MM/YY)	Next Due Date 下次到期日(DD/MM/YY
(1-35) 24	2 x 2kg CO2 14 x 5kg CO2	Portable Fire Extinguishe 2 x 2kg CO2 F.E. 14 x 5kg CO2 F.E.			with FSD requirements with FSD requirements	11/11/2025	10/11/2026 10/11/2026
25	Portable Hand-operated Approved Appliance 2 x Sand Buckets		see attached	Conforms	with FSD requirements	11/11/2025	10/11/2026
						Committee Committee	
Part 2 第	有二部 Installa	ation / Mod	lification / Repair	/ Inspection	work 裝置/改裝/	修理/檢查工作	I a li bi
Code編碼 (1-35)	Type of FSI 裝置類型		Location(s) 位置	Nature of Wor	k Carried out 完成之工作內	容 Comment on Condition 狀	Completion Date 完成日期(DD/MM/
				- NIL -		Stall bacters 1	
	JE ROM PORM		l NTM sa	ndiggs to symply bear up y		deplement to	43
					4.4 (4.1)	ming (R town) from P	
						nation Pratein	ts 12
						destant soul	
	等三部 Defects 損壞事項					ALMLATIA	
Code編碼 (1-35)	Type of FSI 裝置類型		Location(s) 位置	置 Outstanding Defects 未修缺點		Comment on Defects 缺點評述	
	ARMIT		417.65	ישנו לווער ביו און און און און און און און און און או		resuge-limit to the notif	
						nette to anninomic	
	. 8		所別の許える	HI S		e controls and gift	
						er an erp S Trym	
orking orde juipment an time by the	er in accordance with ad Inspection, Testing Director of Fire Servi	the Codes of Pr and Maintenance ces. Defects are lis	pment have been tested ar actice for Minimum Fire of Installations and Equip sted in Part 3. 備經試驗,證明世	Service Installation ment published fron	s and Signature	claim 1	
消防處	處長不時公佈	的最低限度.	之消防裝置及設備 各,損壞事項列於	肯守則與裝置	FSD/RC No. 消防處註冊號碼	KC3/023	Inspec
如證書涉及年檢事項 [,] 應張貼 或處所當眼處以供消防處人					Company Name 公司名稱	Global Engineering Consultants Limited	
	his certificate should be	displayed at promi	消防處人員 nent location of the building of maintenance work is involved	or premises	Telephone 聯絡電話	3100 1924	
					- Date	: 11/11/2025	100

A9707450

第一部 只適用於年檢事項 Part 1 Annual Inspection ONLY

根據 (消防 (裝置及設備)規例) 第八條(1)(b)款,擁有裝置在任何處所內的任何消防裝置或設備的人,須每12個月

由一名註冊承辦商檢查該等消防裝置或設備至少一次。 In accordance with Regulation 8(1)(b) of Fire Service (Installations and Equipment) Regulations, the owner of any fire service installation or equipment withich is installed in any premises shall have such fire service installation or equipment inspected by a registered contractor at least once in every 12 months.

			registered contractor at least once in every 12 months,				
編碼	裝置類型	位置	狀況評述	完成日期	到期日 Due Date		
Code 1-35)	Type of FSI	Location(s)	Comment on Condition	Completion Date (DD/MM/YYYY)	(DD/MM/YYYY)		
1-331				(DD/MINITITY)	(DD/IIIII I I I I I J		
24	Portable Fire Extinguisher						
	2 x 2kg CO2 F.E.	1樓管理處	Conforms with FSD requirements	11/11/2025	10/11/2026		
	14 x 5kg CO2 F.E.	地下發電機房x1,	Conforms with FSD requirements	11/11/2025	10/11/2026		
		地下制櫃房x1,					
		商場管理處x1,					
		天台消防泵房x1,					
		天台升降機房x1,					
		1樓汽水機x2,					
		1樓6號梯x1,					
		2樓電錶房x2,					
		3樓走廊x2,					
		4樓茶水房x1,					
		G/F車場入□x1					
	Portable Hand-operated Approved						
	Appliance						
	2 x Sand Buckets	1樓汽水機	Conforms with FSD requirements	11/11/2025	10/11/2026		