



F.S. NOTES

OTHERS

1. ALL EXIT SIGNS SHALL COMPLY WITH BS 5266-1:2016 AND FSD CIRCULAR LETTER 5/2008 AND TO BE CLEARLY INDICATED BY ILLUMINATED "EXIT 出口" SIGN IN CHINESE AND ENGLISH CHARACTERS OF NOT LESS THAN 125mm HIGH W/ 15mm WIDE STROKES.

2. EMERGENCY LIGHTING SHALL BE REVISED TO BS 5266-1 : 2016 AND BS EN 1838 : 2013 AND FSD CIRCULAR LETTER NO. 4/2021.

PORTABLE FIRE EXTINGUISHER

1. 5KG CO₂ F.E.
2. 5KG DRY POWDER F.E.

LEGEND

- EMERGENCY LIGHT
- EXIT SIGN
- 5KG DRY POWDER F.E.
- 5KG CO₂ F.E.



泛亞消防工程公司
FAN AH FIRE ENGINEERING COMPANY

Unit 4, 16/F, Yue Fung Industrial Building,
No. 35-45 Chai Wan Kok Street, Tsuen Wan, N.T.
TEL : 2414 5811 FAX : 2414 5798 E-MAIL : fanahfire@gmail.com

Proposed Temporary Shop and Services (Sales of Second-hand Private Car, Vehicle Parts and Accessories) with Ancillary Office and Storage Facilities for a Period of 3 Years

ADDRESS: LOTS 3307 RP (PART), 3308 RP (PART),
3312 RP AND 3313 RP IN D.D.104, LONG HA,
YUEN LONG, NEW TERRITORIES

APPLICATION NO.: TPB/ A/YL-KTN/1102

DRAWN NO: F2504-03

SCALE: 1 : 300 @ A3 DRAWN BY: KEITH NG

VER 1 DATE: 11 APR 2025