

1 parking space of 5×2.5 m for private car-6m diameter mechanical turn table for manoeuvring of private car

G/F

Structure 1 Cattery & Caretaker's office (1/F) Car parking space (G/F)GFA: Not exceeding 110m² (including G/F, 1/F and the staircase) Height: Not exceeding 6.5m No. of storey: 2 void Staircase

1/F

Legend:

- 🔯 2m³ F.S water tank 💽 Manual fire alarm call point 🖾 Exit sign 🛭 🗪 Fire alarm bell 🕟 Fire alarm hose reel pump control panel Emergency light

A Hose reel pump

- H.R Hose reel SB Sand bucket
- € 5 Kg CO² gas type fire extinguisher

FS Notes:

- 1. Sufficient emergency lighting shall be provided throughout the entire building in accordance with BS 5266 part 1 and BS EN 1838.
- 2. Sufficient directional and exit sign shall be provided in accordance with BS 5266 part 1 and FSD Circular Letter 5/2008.
- 3. A modified hose reels system supplied by 2m³FS water tank shall be provided. There shall be sufficient hose reels to ensure that every part of each building can be reached by a length of not more than 30m of hose reel tubing.
- 4. Fire alarm system shall be provided to the entire building in accordance with BS 5839: Part 1:2002 + A2:2008 and FSD Circular Letter No. 1/2009 & 1/2012. One actuating point and one audio warning device to be located at each hose reel point. This actuating point should include facilities for fire pump start and audio/visual warning device initiation.
- 5. Portable hand—operated approved appliances shall be provided as required by occupancy.
- 6. Visual fire alarm system shall be provided for the proposed shop in accordance with Barrier Free Access 2008 and FSD Circular Letter 2/2012.
- 7. Secondary power supply will be supplied & connected before the main switch.

PROJECT 項目名稱:	DRAWING TITLE 圖目:	REMARKS 備註:
Temporary Animal Boarding Establishment (Cattery) and Associated Filling of Land and Pond for a Period of 3 Years at Lots 3 S.E (Part) & 8 S.L in D.D.110, Tai Kong Po, Kam Tin, Yuen Long, N.T.	Existing Fire Service System Layout Plan	
	DRAWING No. 圖號:	SCALE 比例:
	FSI-1	1:500