



申請面積: 約 572 平方米

2066

白普理
中心

Bradbury
Communi-
Cen

約20平方米
用作商店及服務行業

TS

約92平方米
用作商店及服務行業

私家車位
5米 x 2.5米
私家車位
5米 x 2.5米

TS

9

283 S.

283 S.C. ss. 6

283

RHWL 221

RHWL 222

283

約20平方米
用作商店及服務行業

約20平方米
用作商店及服務行業

約43平方米
用作商店及服務行業

GLA-TIL

RCP

擬議臨時商店及服務行業 (為期5年)
DD109 Lot 283 S.A RP (部分)

車門口有9米

E

B

D

C

E

D

E

FIRE SERVICE INSTALLATIONS

● STAND-ALONE FIRE DETECTOR

✖ 4 KG DRY POWDER TYPE FIRE EXTINGUISHER

FS NOTES:

- 1) SUFFICIENT STAND-ALONE FIRE DETECTOR SHALL BE PROVIDED THROUGHOUT THE ENTIRE BUILDING IN ACCORDANCE WITH "STAND-ALONE FIRE DETECTOR GENERAL GUIDELINES ON PURCHASE, INSTALLATION & MAINTENANCE [SEP 2021]".
- 2) IN RELATION TO 1) ABOVE, WHERE TWO OR MORE STAND-ALONE FIRE DETECTORS ARE INSTALLED IN AN ENCLOSED STRUCTURE, ALL STAND-ALONE DETECTORS SHALL BE INTERCONNECTED (EITHER WIRED OR WIRELESSLY) SUCH THAT WHEN ONE OF THE STAND-ALONE FIRE DETECTOR IS TRIGGERED, ALL CONNECTED STAND-ALONE FIRE DETECTORS SHALL SOUND AN ALARM SIMULTANEOUSLY.
- 3) PORTABLE HAND-OPERATED APPROVED APPLIANCE SHALL BE PROVIDED AS REQUIRED BY OCCUPANCY.
- 4) ACCESS IS PROVIDED FOR EMERGENCY VEHICLE TO REACH 30m OF ALL PART OF STRUCTURES.

*SITE BOUNDARY FOR IDENTIFICATION PURPOSE ONLY