
寄件者: jeff tang <[REDACTED]>
寄件日期: 2026年06月29日星期一 11:23
收件者: tpbpd/PLAND
副本: Ivan Sze Yuet FUNG/PLAND; chankaisum2003
主旨: 轉寄 : A/YL-KTN/1245 補充資料
附件: A_YL-KTN_1245 - FSIs Proposal (20260624).pdf
類別: Internet Email

電郵標題 : A/YL-KTN/1245 補充資料


=====

致城規會 :

有關規劃申請編號 A/YL-KTN/1245，本人現呈上最新經修改的消防圖一張。如有任何疑問，歡迎聯絡本人。

鄧先生

[從 iPhone 版的 Yahoo Mail 傳送](#)

 申請面積: 約 572 平方米

白普理
中心
Bradbury
Comm
Centre
C
約20平方米
用作商店及服務行業

A
約92平方米
用作商店及服務行業

私家車位
5米 x 2.5米
私家車位
5米 x 2.5米



車門口有9米

D
約20平方米
用作商店及服務行業

E
約20平方米
用作商店及服務行業

B
約43平方米
用作商店及服務行業

FIRE SERVICE INSTALLATIONS

-  STAND-ALONE FIRE DETECTOR
-  4 KG DRY POWDER TYPE FIRE EXTINGUISHER

FS NOTES:

- 1) SUFFICIENT STAND-ALONE FIRE DETECTOR SHALL BE PROVIDED THROUGHOUT THE ENTIRE BUILDING IN ACCORDANCE WITH "STAND-ALONE FIRE DETECTOR GENERAL GUIDELINES ON PURCHASE, INSTALLATION & MAINTENANCE [SEP 2021]".
- 2) IN RELATION TO 1) ABOVE, WHERE TWO OR MORE STAND-ALONE FIRE DETECTORS ARE INSTALLED IN AN ENCLOSED STRUCTURE, ALL STAND-ALONE DETECTORS SHALL BE INTERCONNECTED (EITHER WIRED OR WIRELESSLY) SUCH THAT WHEN ONE OF THE STAND-ALONE FIRE DETECTOR IS TRIGGERED, ALL CONNECTED STAND-ALONE FIRE DETECTORS SHALL SOUND AN ALARM SIMULTANEOUSLY.
- 3) PORTABLE HAND-OPERATED APPROVED APPLIANCE SHALL BE PROVIDED AS REQUIRED BY OCCUPANCY.
- 4) ACCESS IS PROVIDED FOR EMERGENCY VEHICLE TO REACH 30m OF ALL PART OF STRUCTURES.

擬議臨時商店及服務行業 (為期5年)
DD109 Lot 283 S.A RP (部分)

*SITE BOUNDARY FOR IDENTIFICATION PURPOSE ONLY