

Urgent Return receipt Expand Group Restricted Prevent Copy

Belva Yuen King TONG/PLAND

寄件者: Kiff Kit Fu YIU/PLAND
寄件日期: 2026年02月20日星期五 17:11
收件者: Belva Yuen King TONG/PLAND
主旨: Fw: A/YL-LFS/564
附件: 回應土力工程署的擬問 12-02-2026.pdf

From: sun wo wong <[REDACTED]>

Sent: Monday, February 16, 2026 5:52 PM

To: Wilfred Ka Hing CHU/PLAND <wkhchu@pland.gov.hk>; tpbpd/PLAND <tpbpd@pland.gov.hk>

Subject: A/YL-LFS/564

回應土力工程署的擬問

A/YL-LFS/564
回應土力工程署的擬問


Regarding your FI submission for planning application no. A/YL-LFS/564, please find below comments from concerned Government Department for your further action please.

Comments of the Head of Geotechnical Engineering Office, Civil Engineering and Development Department (Contact Officer: Mr. Jeremy WONG; Tel: 2760 5790)

I refer to your email under reference, enclosing the Further Information which includes a Geotechnical Planning Review Report (GPRR) submitted by the applicant. This Office has the following comments on the GPRR.

2. It is noted from Section 2.4 of the GPRR that feature nos. 2SW-C/C84 and 2SW-C/C85 have now been flattened into a gentle sloping ground after some filling works has been done. Please ask the applicant to show the feature boundaries clearly on the survey plan and provide sufficient cross-sections cutting across the proposed site and the whole features to demonstrate that the features would not affect or be affected by the proposed development.

(2SW-C/C84) (2SW-C/C85)
Location Plan



行車路線

出入口大門闊8米

3個私家車車位每個
車位闊2.5米X5米長

2個輕型貨車上落貨車位
每個車位闊3.5米X7米長

商店A面積450平方米
X 8米高 (1層)

消防裝置控制室
面積20平方米X高3.5米 (1層)

商店B面積220平方米
X 8米高 (1層)

洗手間面積15平方
米3.5米高 (1層)

2sw-c/c85(2)

2sw-c/c85(1)

2sw-c/c84(2)

2sw-c/c84(1)

2sw-c/c84(4)

2sw-c/c84(3)

繪於港工務局地圖 E.P. 17 號 in map of D.H.K.C.