

Warehouse for storage of hardware accessories

GFA: 220m² (ABOUT)

No. of Storey: 1

Height: Not exceeding 9m



Project 項目名稱:


Proposed Temporary Open Storage of Hardware Accessories for a Period of 3 Years at Lots 1964 S.A (part) and 1964 S.B (part) in D.D. 129, Lau Fau Shan, Yuen Long, New Territories

Drawing Title 圖紙標題: Remarks 備註: Layout Plan Drawing No. 圖號:

20250808

Light goods vehicle

Structure





Legend:

OO Emergency Lighting

Exit Sign

NATURE OF OCCUPANCY:

Structure (1): 1—Storey Warehouse for storage of hardware accessories. (GFA About: 220sq.m, Height: Not exceeding 9m)

Structure ②: 1-Storey Structure for Site Office.

(GFA: 40sq.m, Height: Not exceeding 3m)

Fire Notes:

- 1.Sufficient emergency lighting shall be provided throughout the entire building in accordance with BS5266—1:2016,BS EN 1838:2013 and the FSD Circular Letter No.4/2021.
- 2.Sufficient directional and exit sign shall be provided in accordance with BS 5266-1:2016 and the FSD Circular Letter No.5/2008.
- 3. Sufficient portable hand—operated approved appliance shall be provided as required by occupancy and as marked on plans.

INTERCEPT FIRE & SECURITY TECHNICIANS LIMITED

Registered Address:

Shop 25 & 84,G/F,Man Fung Building,YLTL329 Fung Kwan Stree, Yuen Long,N.T

Tel: Fax: 24285932

Business Address:

8/F, Block L,Phase 2,Wah Fung Industrial Centre,33—39 Kwai Fung Street Kwai Chung,N.T

Tel: 24255404 , Fax: 24285932

Project:

Proposed Temporary Open Storage of Hardware Accessories

for A Period of 3 years at Lots 1964 S.A (Part) and

1964 S.B (Part) IN D.D,129 Lau Fau Shan,Yuen Long.

Title:

Proposed Fire Service
Installation Layout Plan

Drawn by:	W.C.WONG
Date:	2024-05-03
Scale:	1:300@ A3
Ref No:	TPB/A/YL-LFS/493
Drawing No:	2024/FS/011