

Total: 2 pages

Date: 13 December 2025

TPB Ref.: A/YL-LFS/583

By Email

Town Planning Board
15/F, North Point Government Offices
333, Java Road
North Point
Hong Kong
(Attn: The Secretary)

Dear Sir,

Proposed Temporary Warehouse and Open Storage of Construction Machinery and Construction Materials for a Period of 3 Years at Lots 1822 S.A ss.2, 1822 S.A RP & 1825 in D.D. 129, Lau Fau Shan, Yuen Long, N.T.

Our response to the comments of the AMO, DEVB is as follow:

Comments of AMO, DEVB	Applicant's response
As the application site is partially situated within the Lau Fau Shan Site of Archaeological Interest, the applicant is required to confirm / clarify with the Antiquities and Monuments Office (AMO) whether there is any ground excavation proposed for the development including but not limited to site formation works, drainage works, sewerage works, construction of septic tank etc. If affirmative, the applicant is required to provide details of the proposed works, e.g. the location, extent and depth of the proposed ground excavation for AMO's further comment.	Noted. Ground excavation works is proposed for the proposed surface channel no deeper than 450mm along the site periphery of the application site to the satisfaction of CE/MN, DSD. Chemical toilet is proposed at the application site in order not to provide septic tank and soakaway pit which requires excavation works.

Should you have any enquiries, please feel free to contact our Mr. Patrick Tsui at [REDACTED]
[REDACTED] at your convenience.

Yours faithfully,



Patrick Tsui

c.c. Tuen Mun and Yuen Long West District Planning Office (Attn: Mr. Wilfred CHU) – By Email