

☐Urgent ☐Return receipt ☐Expand Group ☐Restricted ☐Prevent Copy ☐Confidential

Christina Ki Na LEE/PLAND

寄件者: Chong Hermose
寄件日期: 2026年08月31日星期一 23:36
收件者: tpbpd/PLAND
副本: Christina Ki Na LEE/PLAND
主旨: s.16 Planning Application No. A/YL-LFS/623- 回應部門意見
附件: 回應部門意見.pdf

類別: Internet Email

城規會/規劃處：

大家好。

有關 s16 No. A/YL-LFS/623，現附上回應部門意見，請查收。

如有什麼問題，請隨時聯絡我。

謝謝。

Ms Chong

Planning Application No. A/YL-LFS/623

Table A: Responses to Departmental Comments

	Departmental Comments	Responses
	Geotechnical Engineering Office, CEDD (H(GEO), CEDD)	
(a)	“The stability of slope no. 2SW-C/F22(max.5m high) may affect or be affected by the proposed development. The applicant is requested to set up a 4.5m buffer zone from the slope toe, where no construction of structures is permitted. The applicant is reminded to submit the proposed building works to the Buildings Department for approval as required under the provisions of the Buildings Ordinance”	申請人知悉申請地點附近有斜坡，為了避免擬議發展影響該斜坡（編號：2SW-C/F22），申請人會按照部門指示，在距離該斜坡底部的 4.5 米設置一個緩衝區，在緩衝區內不會有任何構築物。