

☐Urgent ☐Return receipt ☐Expand Group ☐Restricted ☐Prevent Copy ☐Confidential

Jane Ching Kei LAU/PLAND

寄件者: [REDACTED]
寄件日期: 2025年09月17日星期三 14:44
收件者: tpbpd/PLAND
副本: Jane Ching Kei LAU/PLAND; [REDACTED]
主旨: Planning Application No. A/YL-MP/390
附件: From vendor Mr Ho 250912.jpg

類別: Internet Email

To whom it may concern,

Attached please find revised page from our vendor, who is now out-of-town till 20/09/2025.

Thank you very much.

Quebeca YU

Mission Ark Ltd

([REDACTED])

11/2/9/2025 2份的再加上2份

SPRINKLER SYSTEM

- 5/2008
9. HOSE REEL PUMPS (ON DUTY AND STANDBY) SHALL BE PROVIDED FOR HOSE REEL SYSTEM.
10. A 2000 LITERS HOSE REEL WATER TANK SHALL BE PROVIDED TO SERVE HOSE REEL SYSTEM.
- EMERGENCY LIGHTING
12. EMERGENCY LIGHTING SHALL BE PROVIDED IN ACCORDANCE WITH BS 5266-1:2016, BS EN 1838:2013 AND THE FSD CIRCULAR LETTER NO. 42021.
13. EMERGENCY LIGHTING SHALL BE PROVIDED IN EVERY COMPARTMENT OF EACH ~~STRUCTURE~~. G/H
- EXIT SIGN AND DIRECTIONAL SIGN
14. SUFFICIENT EXIT SIGN AND DIRECTIONAL SIGN SHALL BE PROVIDED IN ACCORDANCE WITH BS 5839-1:2017 AND THE FSD CIRCULAR LETTER NO. 5/2008. EXIT SIGNS SHALL BE PLACED IN ALL EXIT ROUTES AREA CLEARLY INDICATED.


5/2008
0.420021.

- 6/16

16. PORTABLE FIRE EXTINGUISHERS SHALL BE PROVIDED AT THE POSITION AS SHOWN ON PLANS.

- ON MAIN FIRE ALARM CONTROL PANEL SHALL BE PROVIDED AS INDICATED ON PLANS TO RECEIVE ALL FIRE ALARM SIGNALS.

LEGEND



ABBREVIATION

UL	LOW LEVEL
H/L	HIGH LEVEL
FSD	FIRE SERVICES DEPARTMENT
WSD	WATER SUPPLIES DEPARTMENT
COP	CODE OF PRACTICE
T/A	TO ABOVE
T/B	TO BELOW
F/A	FROM ABOVE