## Gold Rich Planners & Surveyors Ltd.

## 金潤規劃測量師行有限公司

Your Ref.: A/YL-MP/391

Our Ref.: TL25214 / P21087

4 July 2025

The Secretary Town Planning Board 15/F., North Point Government Offices 333 Java Road, North Point, Hong Kong

By E-mail: tpbpd@pland.gov.hk

Dear Sir,

## **Submission of Further Information**

S.16 Application for
"Renewal of Planning Approval for
Temporary Shop and Services (Retail Shop for Hardware Groceries)
with Ancillary Facilities" for a Period of 3 Years
Lot 29 in D. D. 101, Yuen Long, New Territories

We refer to the comments from the Fire Services Department dated 27.6.2025 and Transport Department dated 3.7.2025.

We would like to submit two pages of FS251 certificates for the captioned application.

The traffic trip generation/attraction rates are expected as follows:

	Attractions	Generations
08:30 - 09:30	0	0
09:30 - 10:30	1	. 0
10:30 - 11:30	0	1
11:30 – 12:30	0	0
12:30 - 13:30	0	0
13:30 – 14:30	0	0
14:30 – 15:30	1	0
15:30 – 16:30	0	1
16:30 - 17:30	0	0
17:30 – 18:30	<u>0</u>	<u>0</u>
Total Trips	<u>2</u>	<u>2</u>

Yours faithfully, For and on behalf of Goldrich Planners & Surveyors Ltd.

Francis Lau

Encl.

消防(裝置及設備)規例 A 9256412 FSD Ref.: (Regulation 9(1)) 消防處檔號 第一条 (第九條(1)款) CERTIFICATE OF FIRE SERVICE INSTALLATION AND EQUIPMENT 消防裝置及設備證書 Name of Client: 顧客姓名 Name of Building: Automatic Fixed Installation using Water 思水作滅火劑的自動國家 樓宇名稱 Lot No.29 in D.D.101 Street No./Town Lot: Street/Road/Estate Name: 門牌號數/市地段 街道/屋苑名稱 Yuen Long HK Block: District: Area: 座 分區 地區 香港 九龍 新界 Type of Building 樓字類型: Industrial工業 Composite綜合 Commercial商業 Licensed premises持牌處所 In accordance with Regulation 8(b) of Fire Service (Installations and Equipment) Regulations, the owner of any fire service installation or Part 1 Annual Inspection ONLY equipment which is installed in any premises shall have such fire service installation or equipment inspected by a registered contractor at leasonce in every 12 months. 根據消防(裝置及設備)規例第八條(b)款,擁有裝置在任何處所內的任何消防裝置或設備的人。 一部 只適用於年檢事項 須每12個月由一名註冊承辦商檢查該等消防裝置或設備至少 Code編碼 (1-35) Next Due Date 下次到期日(DD/MM/YY) Completion Date Type of FSI 裝置類型 Location(s) 位置 Comment on Condition 狀況評述 完成日期(DD/MM/YY) 11 7x應急照明燈 As above Conforms with FSD requirements 2-7-2025 1-7-2026 ("a & b" Model : TS-EL 2053) Conforms with FSD requirements 12 2x出口指示燈箱 ! Sign"出口指示 ("Apollo") Alarm System (MFA) 火蓼蓼報系統 Part 2 第 部 Installation / Modification / Repair / Inspection work 裝置/改裝/修理/檢查工作 Code編碼 (1-35) Completion Date 完成日期(DD/MM/YY Type of FSI 裝置類型 Location(s) 位置 Nature of Work Carried out 完成之工作內容 Comment on Condition 狀況評述 Fixed Automatically Operated Approved Appliance 認可的自動操作固定器具 Gas Detection System 氣體偵測系統 Part 3 第 三部 Defects 損壞事項 Code編碼 (1-35) Type of FSI 裝置類型 Location(s) 位置 Outstanding Defects 未修缺點 Comment on Defects 缺點評述 Portable Hand-operated Approved Appliance 認可的人手操 Pressurization of Staircase 模構增壓 **医水泵的環狀水管系統** Ring Main System with Fixed Pump(s) 裝有固 Sprinkler System 花濾 系統 Authorized I/We hereby certify that the above installations/equipment have been tested and found to be in efficient For FSD working order in accordance with the Codes of Practice for Minimum Fire Service Installations and Equipment and Inspection, Testing and Maintenance of Installations and Equipment published from time 受權人簽署 Li Sau Ping to time by the Director of Fire Services. Defects are listed in Part 3. Name: 本人藉此證明以上之消防裝置及設備經試驗,證明性能良好,符 RC 2/163 RC 1/60 Inspected 合消防處處長不時公佈的最低限度之消防裝置及設備守則與裝置 FSD/RC No. 消防處註冊號碼 Intercept Fire & Security 及設備之檢查測試及保養守則的規格,損壞事項列於第三部 Company Name Tech.Ltd 如證書涉及年檢事項,應張貼於大廈 公司名稱 或處所當眼處以供消防處人員查核 Telephone This certificate should be displayed at prominent location of the building or p 聯絡電話 3-7-2025 for FSD's inspection if any annual maintenance work is involved. Date F.S. 251 (Rev. 1/2016) 日期

FIRE SERVICE (INSTALLATIONS AND EQUIPMENT) REGULATIONS