

回應 (EMSD) 擬問

Please note that there is a high pressure underground town gas transmission pipeline (running along San Tam Road) in the vicinity of the proposed temporary workshop.

Having considered the working population provided in the planning statement of the captioned application, EMSD has no adverse comments on this application as far as the proposed workshop will not result in a significant increase in the number of working personnel.

Despite the above, please note that the number of working personnel in the proposed temporary workshop shall be minimized as far as reasonably practicable.

The applicant / works contractor shall therefore liaise with the Hong Kong and China Gas Company Limited in respect of the exact locations of existing or planned gas pipes/gas installations in the vicinity of the proposed work areas and any required minimum set back distance away from them during the design and construction stages of work.

The applicant / works contractor is required to observe the requirements of the Electrical and Mechanical Services Department's Code of Practice on "Avoidance of Damage to Gas Pipes" 2nd Edition for reference. The Code can be downloaded via the following web-link:

[https://www.emsd.gov.hk/filemanager/en/content_286/CoP_gas_pipes_2nd_\(Eng\).pdf](https://www.emsd.gov.hk/filemanager/en/content_286/CoP_gas_pipes_2nd_(Eng).pdf)

有關煤氣管道深藏地底以下，而我等工場並沒有明火產生，我等會在工場入口張貼告示嚴正聲明禁止在工場內吸煙及生火，同時在工場周邊裝置滅火筒加強防止火警的風險，而工場內只有兩部開鐵機，兩部都是油壓裝置，產生火警機會非常輕微，又有滅火筒在傍安放絕對可以減少危險出現。