Please see our response to comments as below table:

Department	Comments	Our Responses		
Director of Environmental Protection	Please confirm the permitted gross vehicle weight of the goods vehicle under the application.	See Attachment 1- alternative page 11 The parking would change from medium goods vehicle to light goods vehicle.		
District Lands Officer, Yuen Long	Please confirm that there is and will not have major material change in development parameters for the existing social welfare facility (錦光元 朗綜合社區服務中心) as compared within the current valid s.16 planning scheme No. A/YL-NSW/299.	We would like to confirm that there is and will not have major material change in development parameters for the existing social welfare facility (錦光元朗綜合社區服務中心) as compared within the current valid s.16 planning scheme No. A/YL-NSW/299.		
Director of Planning Department	According to the submission, a parking space for medium goods vehicle (MGV) is provided. Please justify the use of the MGV parking space.	-We would like to clarify the parking space is for light goods vehicles. The use of the LGV parking space is for loading and unloading donated items such as electrical appliances or furniture for the community, supporting the Food Assistance Service to collect meal boxes, food packs for the families and the elderly.		
	Please clarify the operation hours of the applied social welfare facility.	The operation hours of the applied social welfare facility are as below: Mon-Fri 09:00-18:00 Sat 09:00-13:00 Sun Closed		
	Please clarify the current use of the application site on page 3 of the application form	See Attachment 2- alternative page 3 Since our organization already started community services at this location in 2020, we are now applying to renew and continue using it.		
	Please provide the trip generation and attraction due to the development and assess the traffic impact to Siu Sheung Road and the local assess.	See Attachment 3 – Trip generation & Attraction		
	We would like to clarify that no public announcement system or audio amplification system will be used at the outdoor area of the Site and no adverse traffic impact on Siu Sheung Road is anticipated.			
	Since our organization already started community services at this location in 2020, we have built up a good relationship and network in the community, we are now applying to renew and continue using this location to provide social services for the community.			

Department	Comments	Our Responses
Director of Fire Services	Please submit the latest fire service installations (FSIs) proposal for planning application no. A/YL-NSW/299	See Attachment 4 - FSI
	Please submit the statement/undertaking to confirm that there is no change in the layout and applied uses as compared with the previous application no. A/YL-NSW/299.	We would like to confirm that there is no change in the layout and applied uses as compared with the previous application no. A/YL-NSW/299.
	the applicant is advised to submit a full set of valid F.S. 251(s) covering all the FSIs implemented on the application site for further consideration.	See Attachment 5 – FS251_01 See Attachment 6 – FS251_02

(i)	Gross floor area		sq.m 平方米	Plot Ratio 地積比率
	and/or plot ratio 總樓面面積及/或 地積比率	Domestic 住用	□ About 約 N. A. 不適用 □ Not more than 不多於	□About 約 □Not more than 不多於
		Non-domestic 非住用	□ About 約 □ Not more than 不多於	□About 約 □Not more than 不多於
(ii)	No. of blocks 幢數	Domestic 住用	0	
		Non-domestic 非住用	1	
(iii)	Building height/No. of storeys 建築物高度/層數	Domestic 住用	N. A. 不適用	m 米 □ (Not more than 不多於)
			N. A. 不適用	Storeys(s) 層 □ (Not more than 不多於)
		Non-domestic 非住用	高度: 7.43米	m 米□ (Not more than 不多於)
			共一層	Storeys(s) 層 □ (Not more than 不多於)
(iv)	Site coverage 上蓋面積	N. A. 不適用	I	% □ About 約
(v)	No. of parking spaces and loading /	Total no. of vehicle	e parking spaces 停車位總數	3
	unloading spaces 停車位及上落客貨 車位數目	Motorcycle Parkii Light Goods Vehi Medium Goods V Heavy Goods Veh	ng Spaces 私家車車位 ng Spaces 電單車車位 cle Parking Spaces 輕型貨車泊車 ehicle Parking Spaces 中型貨車泊 nicle Parking Spaces 重型貨車泊車 ecify) 其他 (請列明)	1車位 0
		Total no. of vehicle 上落客貨車位/	e loading/unloading bays/lay-bys 停車處總數	0
		Taxi Spaces 的土 Coach Spaces 旅 Light Goods Vehi Medium Goods V Heavy Goods Veh Others (Please Spa	0 0 0 0 0	

(d)	statutory plan(s)	Approved Nam Sang Wai Outline Zone Plan No.S/YL-NSW/10 南生圍分區計劃大綱核准圖 編號S/YL-NSW/10						
(e)	Land use zone(s) involved 涉及的土地用途地帶	"Undetermined"「未決定用途」						
(f)	Social welfare facility DESCRIPTION OF CURRENT USE(S) USE USE THE SECOND SHORT OF COMMUNITY SECOND USE THE S							
4.	"Current Land Owner	of Application Site 申請地點的「現行土地擁有人」						
The	applicant 申請人 —							
	is the sole "current land owne	^{;#&} (please proceed to Part 6 and attach documentary proof of ownership). ; ^{#&} (請繼續填寫第6部分,並夾附業權證明文件)。						
	is one of the "current land owners" ^{# &} (please attach documentary proof of ownership). 是其中一名「現行土地擁有人」 ^{#&} (請夾附業權證明文件)。							
	is not a "current land owner" [#] . 並不是「現行土地擁有人」 [#] 。							
Ø		on Government land (please proceed to Part 6). 上(請繼續填寫第 6 部分)。						
5.	Statement on Owner's 就土地擁有人的同意	Consent/Notification /通知土地擁有人的陳述						
(a)	involves a total of	he Land Registry as at						
(b)	The applicant 申請人 -							
	* "	f"current land owner(s)"#.						
	, ,	. 名「現行土地擁有人」"的同意。						
	Details of consent of "current land owner(s)" # obtained 取得「現行土地擁有人」 #同意的詳情							
	Land Owner(s) Reg	umber/address of premises as shown in the record of the Land stry where consent(s) has/have been obtained 土地註冊處記錄已獲得同意的地段號碼/處所地址 Date of consent obtained (DD/MM/YYYY) 取得同意的日期 (日/月/年)						
	N. A. 不適用 N.	. 不適用 N. A. 不適用						
	N. A. 不適用 N.	不適用 N. A. 不適用						
		. 不適用 N. A. 不適用						
	(Please use separate sheets if the space of any box above is insufficient. 如上列任何方格的空間不足,請另頁說明)							

Application No: No. A/YL-NSW/347

The trip generation and attraction due to the development and assess the traffic impact to Siu Sheung Road and the local assess:

	Mon	Tue	Wed	Thu	Fri	Sat	Sun
0900-1000	#1,#2 (in)						
1000-1100			#3 (in)		#3 (in)		
1100-1200							
1200-1300			#3 (out)		#3 (out)	#1,#2 (out)	
1300-1400	#1 (out)						
1400-1500							
1500-1600							
1600-1700							
1700-1800	#2 (out)						

Remark:


Private Car 1: #1

Private Car 2: #2

LGV: #3

F.S. NOTES:

- 1. THE SPRINKLER SYSTEM SHALL BE DESIGNED AND INSTALLED IN ACCORDANCE WITH LPC RULES INCORPORATING BS EN 12845: 2003 AND HKFSD CIRCULAR LETTERS NO. 3/2006
- 2. THE HAZARD CLASSIFICATION OF THE SPRINKLER SYSTEM SHALL BE 0H1
- 3. MODIFIED HOSE REEL SYSTEM SHALL BE PROVIDED IN ACCORDANCE WITH CODES OF PRACTICE 2012
- 4. AUTOMATIC FIRE ALARM & DETECTION SYSTEM SHALL BE PROVIDED IN ACCORDANCE WITH LPC RULES OF BS 5839-1: 2002 + A2 2008 AND HKFSD CIRCULAR LETTER NO. 1/2009, 2/2009 & 2/2012 & 3/2010
- 5. VISUAL FIRE ALARM SHALL BE PROVIDED IN ACCORDANCE WITH BS 5839-1:2002 + A2 2008 AND FSD CIRCULAR LETTER NO.2/2012 AND BARRIER FREE ACCESS 2008
- 6. A MANUALLY OPERATED FIRE ALARM SYSTEM C/W MANUAL BREAKGLASS AND ALARM BELL SHALL BE PROVIDED THROUGH THE BUILDING AND INCORPORATED TO THE FH/HR SYSTEM
- 7. ALL BREAK GLASS UNITS SHOULD OPERATE ALL ALARM BELLS AND VISUAL FIRE ALARM AND START THE F.S. FIXED FIRE PUMP AUTOMATICALLY.
- 8. SUFFICIENT EXIT SIGNS AND DIRECTIONAL SIGNS SHALL BE PROVIDED IN ACCORDANCE WITH THE FSD CIRCULAR LETTER NO. 5/2008 AND CONNECTED TO THE POWER SUPPLIES SYSTEM AND WITH 2 HOURS BATTERY BACK UP WILL BE PROVIDED FOR THE ENTIRE DEVELOPMENT TO ENSURE THAT; ALL EXIT ROUTES ARE CLEARLY INDICATED
- 9. EMERGENCY LIGHTING WILL BE DESIGN IN ACCORDANCE WITH BS EN 5266 PT 1 : 2016 AND BS EN 1838 : 2013 AND FSD CIRCULAR LETTER NO. 4/2021
- 10. SELF-CONTAINED LUMINAIRES EMERGENCY LIGHTS WITH 2 HOURS BACK UP SHALL BE PROVIDED TO ALL PUBLIC AREA AND ALL EXIT ROUTES LEADING TO GROUND FLOOR LEVEL
- 11. 37000L SPRINKLER WATER TANK (SIZE: ((5000wX4000d)+(1500wX1400d))X1500h) LOCATED AT ROOF
- 12. 2000L F.S. TANK (SIZE: 2000wX1000dX1500h) LOCATED AT ROOF
- 13. THE SECONDARY POWER SUPPLY WILL BE CONNECTED TO THE SOURCE BEFORE MAIN SWITCH
- 14. FIRE ALARM SIGNALS SHALL BE LINKED TO THE FIRE SERVICES COMMUNICATION CENTRE VIA A FIRE SERVICES DIRECT TELEPHONE LINE
- 15. THE APPROPRIATE TYPE FIRE EXTINGUISHERS SHALL BE PROVIDED AT LOCATIONS AS SHOWN ON PLAN
- 16. THE FLOOR AREAS DO NOT EXCEED 2000M2. THEREFORE, NO AUDIO / VISUAL ADVISORY SYSTEM WILL BE PROVIDED FOR THE ENTIRE BUILDING
- 17. SPLIT TYPE COOLING UNITS ARE ADOPTED AND NO DUCTWORK SYSTEMS ARE INSTALLED IN THE ENTIRE BUILDING. THEREFORE, NO VENTILATION / AIR-CONDITIONING CONTROL SYSTEM WILL BE PROVIDED.



NOTE 備註

REVISION 修改

NO. 编號	REVISION 修改	DATE 日期	BY 修改人
REV.A	Wetal gate, cobinet, parking space	30/09/2021	TC
REV.B		18/11/2021	TC

CONTRACTOR 承建商



PROJECT 工程項目

RENOVATION OF FORMER
SMALL TRADERS NEW VILLAGE
PUBLIC SCHOOL FOR KAM
KWONG INTEGRATED
COMMUNITY SERVICE CENTER
YUEN LONG

DRAWING TITLE 圖紙名稱

FS Plan(AS-BUILT)

SCALE 比例 1 IN 150 (A3)

DRAWING NO. 圖號 FS-001

DRAWN BY 繪製

CHECKED BY 審閱

DATE 日期 09/06/2021

TC

PROJECT NO. 工程編號 LM-SW19-02

FIRE SERVICE (INSTALLATIONS AND EQUIPMENT) REGULATIONS

消防(裝置及設備)規例 (Regulation 9(1))

(Regulation 9(1))

Ser	ial	N	u	mb	er
		_	_		

10401006876

FSD Ref.: 消防處檔號

	CEI	第) RTIFICATE OF FIRE SERV	九條(1)款) //CE INSTAL	LATION AND FOLL		000876	
Name of	Client 顧客姓名		支置及設備認		PMENI		
	ong Integrated Community Se	rvice Center - Yuen Long					
Address							
Former S	Small Traders New Village Publi	c School in D.D.115, Small	Traders Nev	v Village, Nam Sang	Wai, Yuen Long		
Type of Bu	ilding 樓字類型: Industrial 工業	Commercial 商業 Domestic	·住宅 Con	nposite 綜合	d premises 持牌處所	Institut	ional 社團
	ONLY or equipment of equipment	ordance with Regulation 8(b) of the pment which is installed in any preit tonce in every 12 months. 根據消路名註冊承辦商檢查該等消防裝置或該	Fire Service (Inmises shall hav 方(裝置及設備)共	nstallations and Equipment e such fire service installat) Regulations, the owne	er of any fire	e service installation
Code 編碼 (1-35)	Type of FSI 裝置類型	Location(s)位置		t on Condition 狀況評述	Completion Da 完成日期 (DD/MM/YYY)		Next Due Date 下次到期日 DD/MM/YYYY)
11	Emergency Lighting	G/F	(Defects	see Part 3)	16/09/2024		15/09/2025
12	Exit Sign	G/F	Confirm requiren	s with FSD nents	16/09/2024		15/09/2025
Part 2 第	二部 Installation / Modification /	Repair / Inspection works	表置/改裝/修	理/檢查工作			
Code 編碼 (1-35)	Type of FSI 裝置類型	Location(s)位置	Nature	of Work Carried out 完成之工作內容	Comment on Coi 狀況評述	nation	Completion Date 完成日期 (DD/MM/YYYY)
Part 3 第	三部 Defects 損壞事項					5-30	
Code 編碼 (1-35)	Type of FSI 裝置類型	Location(s)位置		Outstanding Defects 5	未修缺點		nent on Defects 缺點評述
11	Emergency Lighting	G/F	1 nos of	emergency light	ing failure	Need	to replace
						- ONLY	
Remark 備	註	M1 (1) (4) (4) (4) (4) (4) (4) (4) (4) (4) (4	14 To 15 To	Authorized Signature: 受權人簽署 Name:			For FSD use only
working ord Equipment time to time 本人藉此證	y certify that the above installations/equip der in accordance with the Codes of Pr and Inspection, Testing and Maintenan by the Director of Fire Services. Defects 明以上之消防裝置及設備經試驗,證明性抗	actice for Minimum Fire Service I ce of Installations and Equipment are listed in Part 3. 能良好,符合消防處處長不時公佈的	nstallations and published from	f FSD/RC No.: 消防處註冊號碼 Company Name:	RC1 / 0401 RC2	<u> </u>	Inspected
	守則與裝置及設備之檢查測試及保養守則	的規格,損壞事項列於第三部.		公司名稱	康威工程有限 2	公司	Key-in
	如證書涉及年檢事項			Telephone			
This	處所當眼處以供》 certificate should be displayed at		ilding or	聯絡電訊			Verified
	ises for FSD's inspection if any a			Date:	27/06/2023		

F.S. 251 (Rev. 01/2012) d1df-ff0d-acca-791d-2e09-f7be-6d8c-6d29




Name of Client 顧客姓名


Kam Kwong Integrated Community Service Center - Yuen Long


Part 1 Annual Maintenance **ONLY**


In accordance with Regulation 8(b) of the Fire Service (Installations and Equipment) Regulations, the owner of any fire service installation or equipment which is installed in any premises shall have such fire service installation or equipment inspected by a registered contractor at least once in every 12 months. 根據消防(裝置及設備)規例第八條(b)款,擁有裝置在任何處所內的任何消防裝置或設備的人, 須每12個月由一名註冊承辦商檢查該等消防裝置或設備至少一次。 第一部只適用於年檢事項


	,2日 日本市外市内水山以4万万农园北欧洲工2 人。					
Code 編碼 (1-35)	Type of FSI 裝置類型	Location(s)位置	Comment on Condition 狀況評述	Completion Date 完成日期 (DD/MM/YYYY)	Next Due Date 下次到期日 (DD/MM/YYYY)	
13	Fire Alarm System (MFA)	G/F	Confirms with FSD requirements	16/09/2024	15/09/2025	
15	Fire Detection System	G/F	Confirms with FSD requirements	16/09/2024	15/09/2025	
23	Hose Reel	G/F	Confirms with FSD requirements	16/09/2024	15/09/2025	
28	Sprinkler System	G/F	Confirms with FSD requirements	16/09/2024	15/09/2025	














Kam Kwong Integrated Community Service Center - Yuen Long





FIRE SERVICE (INSTALLATIONS AND EQUIPMENT) REGULATIONS

消防(裝置及設備)規例 (Regulation 9(1))

Serial	Number

FSD Ref.: [
消防處檔號	

713173 Mai (M)	OFD.	(第) TIEIOATE OF FIDE OFFI	九條(1)款)	"		81 01424	8
		TIFICATE OF FIRE SERVI 消防型	CE INSTAI 置及設備部		JIPMENT		
	Client 顧客姓名			48		,	
L	ong Integrated Community Ser	vice Center - Yuen Long		272711		(m) o'.	7246946
Address							400000
Former !	Small Traders New Village Public	School in D.D.115, Small T	raders Nev	v Village, Nam San	g Wai, Yuen Long		
Type of Bu	ilding 樓宇類型: Industrial 工業	Commercial 商業 Domestic	住宅 Con	nposite 綜合 XLicens	ed premises 持牌處所	Instit	utional 社團
	ONLY or equip	dance with Regulation 8(b) of the F ment which is installed in any pren once in every 12 months. 根據消防 公註冊承辦商檢查該等消防裝置或設	nises shall hav i(裝置及設備)共	e such fire service install	lation or equipment inco	nected by a	registered contractor
Code 編碼 (1-35)	Type of FSI 裝置類型	Location(s)位置	T	t on Condition 狀況評	Completion [述 完成日期 (DD/MM/YY		Next Due Date 下次到期日 (DD/MM/YYYY)
24	Portable Fire Extinguisher 5 Kg CO2 F.E. x 5 nos	G/F	Confirm requirer	s with FSD nents	16/09/202	24	15/09/2025
Part 2 第	二部 Installation / Modification / F	Repair / Inspection works 裝	置/改裝/修	理/檢查工作	340.41		
Code 編碼 (1-35)	Type of FSI 裝置類型	Location(s)位置			Comment on C 狀況評論		Completion Date 完成日期 (DD/MM/YYYY)
Dort 2 SE	三部 Defects 損壞事項						
Code	二印 Delects 頂機事項		<u> </u>				
編碼 (1-35)	Type of FSI 裝置類型	Location(s)位置	Outstanding Defects 未修缺點		Com	Comment on Defects 缺點評述	
Remark 備	註			Authorized Signature: 受權人簽署 Name:		1.	For FSD use only
working ord Equipment time to time 本人藉此證	y certify that the above installations/equipn der in accordance with the Codes of Pra- and Inspection, Testing and Maintenance by the Director of Fire Services. Defects a 明以上之消防裝置及設備經試驗,證明性能 守則與裝置及設備之檢查測試及保養守則的	ctice for Minimum Fire Service In e of Installations and Equipment re listed in Part 3. 良好,符合消防處處長不時公佈的攝	stallations and published fron	f FSD/RC No.: 消防處註冊號碼	RC3 / 0681 RC		Inspected
EX INT \X (1X IM)	如證書涉及年檢事項,			ムりつ件			,
This	處所當眼處以供消	的處人員查核	l.d.	Telephone: 聯絡電話		6 140	Verified
prem	This certificate should be displayed at prominent location of the building or premises for FSD's inspection if any annual maintenance work is involved.				16/09/2024		

F.S. 251 (Rev. 01/2012) cf8e-d5e3-1a75-eac8-8397-8cc2-7548-a0e8



Kam Kwong Integrated Community Service Center - Yuen Long

