By Post and By E-mail (kkcc@kamkwongchurch.org; rita.tang@kkicsc.org)

February 18, 2022

Our Ref: LM-SW19-02-074 Your Ref:--

Yuen Long Kam Kwong Church Ltd.

Dear Madam,

Provision of Revised Fire Services Installation Plan Renovation of Former Small Traders New Village Public School for Kam Kwong Integrated Community Service Center – Yuen Long D.D.115, Small Traders New Village, Nam Sang Wai, Yuen Long

Further to ad-hoc meeting dated February 17, 2022, we would like to enclose herewith the Revised Fire Services Installation Plan with additional requirements from Fire Services Department requesting to upgrade the existing Fire Services Installations at the subject premises for your onward submission. Please note that we had also transmitted the same to you via email on February 17, 2022.

Meanwhile, the main contractor would review on the works required to be executed to upgrade on the existing Fire Services Installations and provide a summary with estimated cost by the end of this week.

Should you have any queries, please contact our

Yours faithfully,

For and on behalf of Lee Mark Architecture and Surveying Limited

Director

JM/PH/tw(1434)

Encl.


c.c.

Shun Yip Construction Company Limited –



F.S. NOTES:

- 1. THE SPRINKLER SYSTEM SHALL BE DESIGNED AND INSTALLED IN ACCORDANCE WITH LPC RULES INCORPORATING BS EN 12845: 2003 AND HKFSD CIRCULAR LETTERS NO. 3/2006
- 2. THE HAZARD CLASSIFICATION OF THE SPRINKLER SYSTEM SHALL BE 0H1
- 3. MODIFIED HOSE REEL SYSTEM SHALL BE PROVIDED IN ACCORDANCE WITH CODES OF PRACTICE 2012
- 4. AUTOMATIC FIRE ALARM & DETECTION SYSTEM SHALL BE PROVIDED IN ACCORDANCE WITH LPC RULES OF BS 5839-1: 2002 + A2 2008 AND HKFSD CIRCULAR LETTER NO. 1/2009, 2/2009 & 2/2012 & 3/2010
- 5. VISUAL FIRE ALARM SHALL BE PROVIDED IN ACCORDANCE WITH BS 5839-1:2002 + A2 2008 AND FSD CIRCULAR LETTER NO.2/2012 AND BARRIER FREE ACCESS 2008
- 6. A MANUALLY OPERATED FIRE ALARM SYSTEM C/W MANUAL BREAKGLASS AND ALARM BELL SHALL BE PROVIDED THROUGH THE BUILDING AND INCORPORATED TO THE FH/HR SYSTEM
- 7. ALL BREAK GLASS UNITS SHOULD OPERATE ALL ALARM BELLS AND VISUAL FIRE ALARM AND START THE F.S. FIXED FIRE PUMP AUTOMATICALLY.
- 8. SUFFICIENT EXIT SIGNS AND DIRECTIONAL SIGNS SHALL BE PROVIDED IN ACCORDANCE WITH THE FSD CIRCULAR LETTER NO. 5/2008 AND CONNECTED TO THE POWER SUPPLIES SYSTEM AND WITH
- 2 HOURS BATTERY BACK UP WILL BE PROVIDED FOR THE ENTIRE DEVELOPMENT TO ENSURE THAT; ALL EXIT ROUTES ARE CLEARLY INDICATED
 9. EMERGENCY LIGHTING WILL BE DESIGN IN ACCORDANCE WITH BS EN 5266 PT 1: 2016 AND BS EN 1838: 2013 AND FSD CIRCULAR LETTER NO. 4/2021
- 10. SELF-CONTAINED LUMINAIRES EMERGENCY LIGHTS WITH 2 HOURS BACK UP SHALL BE PROVIDED TO ALL PUBLIC AREA AND ALL EXIT ROUTES LEADING TO GROUND FLOOR LEVEL
- 11. 37000L SPRINKLER WATER TANK (SIZE: ((5000wX4000d)+(1500wX1400d))X1500h) LOCATED AT ROOF
- 12. 2000L F.S. TANK (SIZE: 2000wX1000dX1500h) LOCATED AT ROOF
- 13. THE SECONDARY POWER SUPPLY WILL BE CONNECTED TO THE SOURCE BEFORE MAIN SWITCH
- 14. FIRE ALARM SIGNALS SHALL BE LINKED TO THE FIRE SERVICES COMMUNICATION CENTRE VIA A FIRE SERVICES DIRECT TELEPHONE LINE
- 15. THE APPROPRIATE TYPE FIRE EXTINGUISHERS SHALL BE PROVIDED AT LOCATIONS AS SHOWN ON PLAN
- 16. THE FLOOR AREAS DO NOT EXCEED 2000M2. THEREFORE, NO AUDIO / VISUAL ADVISORY SYSTEM WILL BE PROVIDED FOR THE ENTIRE BUILDING
- 17. SPLIT TYPE COOLING UNITS ARE ADOPTED AND NO DUCTWORK SYSTEMS ARE INSTALLED IN THE ENTIRE BUILDING. THEREFORE, NO VENTILATION / AIR-CONDITIONING CONTROL SYSTEM WILL BE PROVIDED.



NOTE 備註

REVISION 修改

NO. 编號	REVISION 修改	DATE 日期	BY 修改人
REV.A	Wetal gate, cabinet, parking space	30/09/2021	TC
REV.B		18/11/2021	TC
3			
			-

CONTRACTOR 承建商



PROJECT 工程項目

RENOVATION OF FORMER
SMALL TRADERS NEW VILLAGE
PUBLIC SCHOOL FOR KAM
KWONG INTEGRATED
COMMUNITY SERVICE CENTER YUEN LONG

DRAWING TITLE 圖紙名稱

FS Plan(AS-BUILT)

SCALE 比例 1 IN 150 (A3)

DRAWING NO. 圖號 FS-001

FS-001

TC CHECKED BY 審閱

DATE 日期

09/06/2021

PROJECT NO. 工程编號 LM-SW19-02