

Response-to-Comment (RtC)

Proposed Temporary Container Vehicle Park and Open Storage of Construction Materials and Machinery with Ancillary Facilities for a Period of 3 Years in “Government, Institution or Community” Zone and Area shown as ‘Road’, Various Lots in D.D. 104, Ngau Tam Mei, Yuen Long, New Territories

(S.16 Application No. A/YL-NTM/487)

(i) An RtC table:

Departmental Comments		Applicant’s Responses
1. Comments of the Director of Fire Services (D of FS)		
(a)	A sufficient number of stand-alone fire detectors shall be provided at every structure within the application site.	An additional fire detector is proposed in each of the structure. The revised proposal is enclosed for your information (Plan 1).
(b)	The applicant is reminded that if the proposed structures are required to comply with the Buildings Ordinance (Cap. 123), detailed fire safety requirements will be formulated upon receipt of the formal submission of general building plans.	Noted.