

PROPOSED FIRE SERVICE INSTALLATION LAYOUT PLAN

Fire Notes:

1. Sufficient portable hand-operated approved appliance shall be provided as required by occupancy and as marked on plans.
2. Stand-alone fire detector shall be provided for each structure as marked on plans. where two or more stand-alone fire detectors are installed in an enclosed structure, all detectors shall be interconnected (either wire or wirelessly) such that when one of the detectors is triggered, all connected detectors shall sound an alarm simultaneously. and
3. The Stand-alone fire detector shall be provided in accordance with the "Stand-alone Fire Detector General Guidelines on Purchase, installation & Maintenance [Sep 2021]".

Scale 1 : 1000

@ stand-alone Fire Detector

* 4kg dry powder type fire extinguisher

