

☐Urgent ☐Return receipt ☐Expand Group ☐Restricted ☐Prevent Copy

Tommy Ngo Chun MA/PLAND

寄件者: king king <[REDACTED]>
寄件日期: 2025年07月17日星期四 16:27
收件者: tpbpd/PLAND
副本: Tommy Ngo Chun MA/PLAND; Eva Ka Yan TAM/PLAND; Momo Hei Ching
CHOW/PLAND
主旨: A/YL-TT/714
類別: Internet Email

Dear Sir,

Septic tank and soakaway system will be provided at the application site. The septic tank and soakaway system will be designed and constructed according to the requirements of EPD's ProPECC PN 1/23, including requirements for minimum clearance distance, percolation test and certification by Authorized Person.

Best Regards,

Patrick Tsui

Mobile: [REDACTED]

☐Urgent ☐Return receipt ☐Expand Group ☐Restricted ☐Prevent Copy

Tommy Ngo Chun MA/PLAND

寄件者: Tommy Ngo Chun MA/PLAND
寄件日期: 2025年07月17日星期四 16:12
收件者: [REDACTED]
副本: Eva Ka Yan TAM/PLAND; Momo Hei Ching CHOW/PLAND
主旨: Application No. A/YL-TT/714 - Departmental Comments (EPD)

Dear Patrick,

As per your request, below please find the comments from **Environmental Protection Department (Contact Person: Jeremy FONG, Tel: 2835 2164):**

Confirm whether the toilet indicated in the layout plan is a portable toilet, if affirmative, whether licensed collectors will be arranged to collect and dispose the sewage and waste from the proposed use. If not, please advise whether septic tank and soakaway system will be provided. If affirmative, whether the septic tank and soakaway system will be designed and constructed according to the requirements of EPD's ProPECC PN 1/23, including requirements for minimum clearance distance, percolation test and certification by Authorized Person.

Regards,
Tommy MA
Tuen Mun & Yuen Long West District Planning Office
Planning Department
Tel.: 2158 6201