

收件者: tpbpd/PLAND
主旨: Fw: A/YL-TT/728 (Departmental Comments)
附件: TT728New Layout Plan - 複製.pdf; TT728new paved area plan - 複製.pdf; TT728回應
EPD意見..pdf

Sent: Thursday, September 18, 2025 4:40 PM
To: Eva Ka Yan TAM/PLAND <ekytam@pland.gov.hk>
Subject: Re: A/YL-TT/728 (Departmental Comments)

更新申請編號:A/YL/TT728 布局圖&填土圖,以及回應部門意見


Further Information for Planning Application No.A/YL/TT728

Response to comment


Comments from EPD

Comment	Response
Please confirm that wheather septic tank and soakaway system will be provided and if affirmative,wheather the septic tank and soakaway system will be designed and constructed according to the requirements of EPD's ProPECC PN 1/23,including requirements for minimum clearance distance,percolation test and certification by Authorized Person.	No toilet will be provided within the site.As such,no septic tank and soakaway system will be provided.
No septic tank and soakaway system will be provided.Please ask the applicant to clarify how the wastewater generated from the proposed use(e.g.faeces and urine from the animals	The applicant will recruit licensed collectors to collect and dispose the sewage and waste from the site

Layout Plan



Paved Area Plan



The site will paved with concrete at a depth of 0.15m to provide a suitable level and waterproof surface for erection of structures, activity area for dogs and car paking

Paved area with concrete (proposing)
Area: About 1370 m²
Paved ratio :about 83%

Paved area with concrete(existing)
Area :about 275 m²
Paved ratio :about 17 %

 Paved area(regularisation of filling of land)

 Paved area (Proposed filling of land)

Site area: about 1645 m²