

寄件者: Tam Gary [REDACTED]
寄件日期: 2026年03月10日星期二 13:11
收件者: tpbpd/PLAND
副本: Kevin Ting Hong LAM/PLAND
主旨: A/YL-TT/753 Departmental Comments (回應部門意見)

類別: Internet Email

第一點：

Comments from EPD (Contact Person: Mr. FONG, Tel: 2835 2164)

Please confirm whether the toilet indicated in the layout plan is portable toilet, if affirmative, whether licensed collectors will be arranged to collect and dispose the sewage and waste from the proposed use. If not, please advise whether septic tank and soakaway system will be provided. If affirmative, whether the septic tank and soakaway system will be designed and constructed according to the requirements of EPD's ProPECC PN 1/23, including requirements for minimum clearance distance, percolation test and certification by Authorized Person.

本公司現作出以下回應：

該洗手間為流動洗手間，主要給公司現時3名工作人員使用，多為排解小事情而設置，並不經常性使用，而本公司會定期找合資格人士，平均4個月至半年時間會做一次。

第二點：

本公司現作出以下回應：

就有關土地上的問題，該使用的地方在本公司購買時已作出土地平整，現是次申請中目的是規管化原有的填土。