

Total: 1 page

Date: 23 March 2026

TPB Ref.: A/YL-TT/755

By Email

Town Planning Board  
15/F, North Point Government Offices  
333, Java Road  
North Point  
Hong Kong  
(Attn: The Secretary)

Dear Sir,

**Temporary Warehouse for Storage of Construction Materials and Associated Filling of Land for a Period of 3 Years at Lot 2224 (Part) in D.D. 118, Yuen Long, New Territories**

Septic tank and soakaway system will be provided. The septic tank and soakaway system will be designed and constructed according to the requirements of EPD's ProPECC PN 1/23, including requirements for minimum clearance distance, percolation test and certification by Authorized Person.

Should you have any enquiries, please feel free to contact our Mr. Patrick Tsui at [REDACTED] [REDACTED] at your convenience.

Yours faithfully,

  


Patrick Tsui

c.c. [REDACTED]  
[REDACTED]