

☐Urgent ☐Return receipt ☐Expand Group ☐Restricted ☐Prevent Copy

Spencer Ka Tsun LEUNG/PLAND

寄件者: tmylwdpo_pd/PLAND
寄件日期: 2025年06月11日星期三 16:16
收件者: Edwin Wai Shing YEUNG/PLAND
副本: Wai Lap TANG/PLAND; Spencer Ka Tsun LEUNG/PLAND
主旨: 轉寄: Application No. A/YL-TYST/1312 - Response to Departmental Comments

From: tpbbpd/PLAND <tpbbpd@pland.gov.hk>
Sent: Wednesday, June 11, 2025 4:02 PM
To: tmylwdpo_pd/PLAND <tmylwdpo@pland.gov.hk>
Cc: Kiff Kit Fu YIU/PLAND <kkfyiu@pland.gov.hk>
Subject: Fw: Application No. A/YL-TYST/1312 - Response to Departmental Comments

From: pak yeung Yung <[REDACTED]>
Sent: Wednesday, June 11, 2025 3:59 PM
To: tpbbpd/PLAND <tpbbpd@pland.gov.hk>
Cc: Edwin Wai Shing YEUNG/PLAND <ewsyeung@pland.gov.hk>
Subject: Application No. A/YL-TYST/1312 - Response to Departmental Comments

Dear Sir/Madam,

I refer to EPD's comments conveyed by DPO/TMYL and provide our response as follows:

We confirm that septic tank and soakaway will be provided and such system will be designed and constructed with reference to the Practice Note for Professional Person (ProPECC) PN 1/23 (Justification (f) refers), including requirements for minimum clearance distance, percolation test and certification by Authorized Person. The proposed toilet is a flush toilet with sewage discharged to the proposed septic tank.

Regards,

P.Y. Yung
for CTA Limited