

☐Urgent ☐Return receipt ☐Expand Group ☐Restricted ☐Prevent Copy

Spencer Ka Tsun LEUNG/PLAND

寄件者: tmylwdpo_pd/PLAND
寄件日期: 2025年06月27日星期五 9:20
收件者: Edwin Wai Shing YEUNG/PLAND
副本: Wai Lap TANG/PLAND; Spencer Ka Tsun LEUNG/PLAND
主旨: 轉寄: A/YL-TYST/1315進一步資料
附件: 消防裝置建議計劃圖.pdf

From: tpbpd/PLAND <tpbpd@pland.gov.hk>
Sent: Friday, June 27, 2025 9:05 AM
To: tmylwdpo_pd/PLAND <tmylwdpo@pland.gov.hk>
Cc: Kiff Kit Fu YIU/PLAND <kkfyiu@pland.gov.hk>; Yuki Man Yin YIU/PLAND <ymyyiu@pland.gov.hk>
Subject: Fw: A/YL-TYST/1315進一步資料

From: 陳灝然 <[REDACTED]>
Sent: Friday, June 27, 2025 4:57 AM
To: tpbpd/PLAND <tpbpd@pland.gov.hk>
Cc: Edwin Wai Shing YEUNG/PLAND <ewsyeung@pland.gov.hk>; Spencer Ka Tsun LEUNG/PLAND <sktleung@pland.gov.hk>
Subject: A/YL-TYST/1315進一步資料

敬啟者

就上述檔案，申請人現提交進一步資料以回應部門意見。

申請地點作臨時貨倉存放食品，在場地營運方面，場地不會存放肉類，不論是凍肉或新鮮肉類皆不會儲存。場地主要儲存罐頭及生果，所有食品皆為獨立包裝，因此食品方面不會衍生任何污水問題。場地不會進行食品加工、洗滌或烹調工作，場地用途只作存放食品的臨時貨倉。

洗手間排污方面，場地洗手間是臨時式廁所，會有便槽，便槽底部空間供儲存糞便，儲存容量為600升。作業者會定期聘請專業技術人員進行吸糞工作，所有污水皆獨立儲存在流動洗手間內。洗手間污水不會排放到場內排水系統，故場地不需設置化糞池。

此外，附件為消防裝置建議計劃圖。



消防裝置建議計劃圖

⊗ 四公斤乾粉滅火筒

共安裝五支四公斤乾粉滅火筒，位置分別於場地四周及構築物附近，每隔約40米安裝一支四公斤乾粉滅火筒。場地共有五個構築物，基於以上條件，申請人建議在申請範圍內安裝五支四公斤乾粉滅火筒。

構築物(1)

用途：食品儲存
建築物料：以金屬搭建
高度：約9米
層數：2層
上蓋面積：約1835平方米
總樓面面積：約2635平方米

構築物(2)

用途：辦公室及洗手間
建築物料：以金屬搭建
高度：約4米
層數：1層
上蓋面積：約57平方米
總樓面面積：約57平方米

構築物(3)

用途：消防泵房
建築物料：以金屬搭建
高度：約4米
層數：1層
上蓋面積：約22平方米
總樓面面積：約22平方米

構築物(4)

用途：機械設施
建築物料：以金屬搭建
高度：約3米
層數：1層
上蓋面積：約5平方米
總樓面面積：約5平方米

構築物(5)

用途：機械設施
建築物料：以金屬搭建
高度：約3米
層數：1層
上蓋面積：約5平方米
總樓面面積：約5平方米

● ● ● 行車路線

SCALE 1 : 1000