

**Claire CHAN**

---

**From:** [REDACTED]  
**To:** Michael LING  
**Subject:** RE: Request for supporting documentation on Air Quality Emissions from Eastern Harbour Crossing Ventilation Building

**From:** PL Wong (EHC) [REDACTED]  
**Sent:** Monday, June 2, 2025 18:39  
**To:** Michael LING [REDACTED]  
**Cc:** Alex CHEUNG [REDACTED]

Tommy KONG

**Subject:** RE: Request for supporting documentation on Air Quality Emissions from Eastern Harbour Crossing Ventilation Building

**This Message Is From an Untrusted Sender**

You have not previously corresponded with this sender.

Dear Mr. Ling,

Eastern Harbour Crossing Ventilation Building installed with a ventilation system which supplies fresh air for adequate dilution of gases and smoke emitted from vehicles through the tunnel. Some extract fans are also installed to minimize the amount of polluted air leaving the tunnel. Under emergency situation, the system extract smoke away from the tunnel tubes through the air outlet at the roof of the ventilation building. Normally, there is no excessive pollutant emitting from the ventilation building under normal circumstances. Moreover, please see the indication on the attached file showing the In/Out air duct position for your reference.

Regards,

PL Wong  
Chief Engineering Controller  
Pacific Infrastructure Limited  
[REDACTED]  
Fax : 2347 5037

---

**From:** Michael LING [REDACTED]  
**Sent:** Monday, June 2, 2025 5:16 PM  
**To:** PL Wong (EHC) [REDACTED]  
**Cc:** Alex CHEUNG [REDACTED]; Tommy KONG [REDACTED]  
**Subject:** RE: Request for supporting documentation on Air Quality Emissions from Eastern Harbour Crossing Ventilation Building

Dear Mr. Wong,

Regarding our recent discussion, can you please clarify the Ventilation under the management of Eastern Harbour Tunnel, kindly please advise if you can provide supporting documentation, or statement to confirm if there is no pollutants would be emitted from the ventilation building under normal circumstances.

