

1. Responses to Comments from Environmental Protection Department (EPD)

Item	Departmental Comments	The Applicant's Responses
EPD(1)	<p><u>EPD's Comments on SIA (Document No. R9427 V2.0 SIA.docx)</u></p> <p>1. Section 2.3.2: The sewage flow rate and peak flow of the employee of the site do not tally with Appendix 2.1 Table 1. Please revise.</p>	Section 2.3.2 is revised (see Appendix A).
EPD(2)	<p>2. Appendix 2.1 Table 2: The invert level of FMH1001408 in the table (13.63 mPD) does not tally with remark 5 (16.625 mPD). Please revise.</p>	Remark 5 is revised. The invert level of FMH1001408 is measured to be 13.625mPD during CCTV survey, which is rounded to 2 d.p. for calculation (see Appendix A).

2. Responses to Comments from Drainage Services Department (DSD)

Item	Departmental Comments	The Applicant's Responses
DSD(1)	<p>2. Please be reminded that if the captioned application is approved, a condition should be included to request the applicant to submit and implement the drainage proposal for the site to the satisfaction of Director of Drainage Services or the TPB to ensure that it will not cause adverse drainage impact to the adjacent area.</p>	Noted.
DSD(2)	<p>3. The applicant should have its own stormwater collection and discharge system to cater for the runoff generated within the Site and overland flow from surrounding of the Site, e.g. surface channel of sufficient size along the perimeter of the Site; sufficient openings should be provided at the bottom of the boundary wall/fence to allow surface runoff to pass through the Site if any boundary wall/fence are to be erected. Any existing flow path affected should be re-provided. The applicant should neither obstruct overland flow nor adversely affect the existing natural streams, village drains, ditches and the</p>	Noted. The information will be provided in the future drainage proposal to be submitted for discharging the planning approval condition as suggested by DSD in #1 above after the subsequent s.16 planning application is approved by the Town Planning Board or during the land administrative application period.