

Government Departments with No Objection / No Adverse Comment

The following government departments have no objection to or no adverse comment on the application:

- (a) District Lands Officer/Yuen Long, Lands Department;
- (b) Commissioner for Transport;
- (c) Chief Building Surveyor/New Territories West, Buildings Department;
- (d) Chief Engineer/Construction, Water Supplies Department;
- (e) Chief Engineer/Mainland North, Drainage Services Department;
- (f) Chief Highway Engineer/New Territories West, Highways Department;
- (g) Director of Environmental Protection;
- (h) Director of Fire Services;
- (i) Chief Engineer/Cross-Boundary Infrastructure and Development, Planning Department;
- (j) Comments of the Project Manager (West), Civil Engineering and Development Department;
- (k) District Officer (Yuen Long), Home Affairs Department; and
- (l) Commissioner of Police.

Recommended Advisory Clauses

- (a) to resolve any land issues relating to the development with the concerned owner(s) of the application site (the Site);
- (b) to note the comments of the District Lands Officer/Yuen Long, Lands Department (DLO/YL, LandsD) that:
 - the Site comprises Old Schedule Agricultural Lot held under the Block Government Lease which contains the restriction that no structures are allowed to be erected without the prior approval of the Government;
 - Lot nos. 1567 RP and 1570 in D.D. 121 are covered by Short Term Waiver (STW) Nos. 4474 and 4475 for temporary public vehicle park for private cars and light goods vehicle;
 - the STW holder(s) will need to apply to his office for modification of the STW conditions where appropriate and the lot owner(s) without STW shall apply to his office for a STW to permit the structure(s) erected within the said private lots. The application(s) for STW will be considered by the Government in its capacity as a landlord and there is no guarantee that it will be approved. The STW, if approved, will be subject to such terms and conditions, including the payment of waiver fee and administrative fee as considered appropriate by his department. Besides, given the proposed use is temporary in nature, only erection of temporary structure(s) will be considered;
- (c) to note the comments of the Commissioner for Transport that (C for T) that:
 - sufficient space should be provided within the Site for manoeuvring of vehicles. In addition, no vehicles are allowed to queue back to public roads or reverse onto/from public roads; and
 - the local track leading to the Site is not under Transport Department's purview. The applicant shall obtain consent of the owners/managing parties of the local track for using it as the vehicular access to the Site;
- (d) to note the comments of the Chief Highway Engineer/New Territories West, Highways Department (CHE/NTW, HyD) that:
 - his department shall not be responsible for the maintenance of any access connecting the Site and Shan Ha Road; and
 - adequate drainage measures should be provided to prevent surface water running from the Site to the nearby public roads and drains;
- (e) to note the comments of the Chief Engineer/Mainland North, Drainage Services Department (CE/MN, DSD) that for any change of existing ground level and associated works proposed by the applicant that could affect adjacent land and cause other impacts and/or other issues to public, please submit technical assessment(s) in other aspect(s) and seek comment from relevant departments as necessary;
- (f) to note the comments of the Director of Environmental Protection (DEP) that the relevant mitigation measures and requirements in the latest "Code of Practice on Handling the Environmental Aspects of Temporary Uses and Open Storage Sites" should be followed to minimise any potential environmental nuisances on the surrounding areas; and

(g) to note the comments of the Chief Building Surveyor/New Territories West, Buildings Department (CBS/NTW, BD) that:

- if the existing structures (not being a New Territories Exempted House) are erected on leased land without the approval of the Buildings Department (BD), they are unauthorised building works (UBW) under the Buildings Ordinance (BO) and should not be designated for any proposed use under the captioned application;
- for UBW erected on leased land, enforcement action may be taken by the BD to effect their removal in accordance with the prevailing enforcement policy against UBW as and when necessary. The granting of any planning approval should not be construed as an acceptance of any existing building works or UBW on the Site under the BO;
- before any new building works (including containers/ open shed as temporary buildings) are to be carried out on the Site, prior approval and consent of the BD should be obtained, otherwise they are UBW. An Authorised Person should be appointed as the co-ordinator for the proposed building works in accordance with the BO;
- the Site shall be provided with means of obtaining access thereto from a street and emergency vehicular access in accordance with Regulations 5 and 41D of the Building (Planning) Regulations (B(P)R) respectively; and
- the Site does not abut on a specified street of not less than 4.5m wide and its permitted development intensity shall be determined under Regulation 19(3) of the B(P)R at building plan submission stage.