

Urgent Return Receipt Requested Sign Encrypt Mark Subject Restricted Expand personal&public g



RE: Planning Application No. A/NE-SSH/145 - Comments from EPD
21/11/2022 15:42

From: "YING, Michelle Mei Suet"
To: "cyklo@pland.gov.hk" <cyklo@pland.gov.hk>
Cc: "CHAN, Sam Sun Yau" , "Lee, Man Tok"

Sent by:

History: This message has been forwarded.

Dear Candice,

Regarding our application No. A/NE-SSH/145, we would like to have a deferral request for further information submission.

Deferral period

2 months

Reason

Preparing the document about landowner (Tin Liu Village House No. 120).

Michelle Ying

Assistant Engineer

Distribution Circuits

Kum Shing (K.F.) Construction Company Limited

Kum Shing Group 金城營造集團

From: YING, Michelle Mei Suet

Sent: Monday, 14 November, 2022 4:24 PM

To: cyklo@pland.gov.hk

Cc: CHAN, Sam Sun Yau

Subject: RE: Planning Application No. A/NE-SSH/145 - Comments from EPD

Dear Candice,

CLP received an electricity supply application for one village houses No. 120 at Tin Liu Village. We would like to reply to you in the following notes.

1. For the voltage level, there is a LV cable laying which is 380V.
2. The proposed works would not involve tree felling.
3. There is a tree on the linear distance. To avoid the tree, the proposed cable route is the best routing with least environmental impact.
4. 0.55m is a standard depth. 1.2m is our estimate depth. To prevent any blocks under the ground, an estimated depth is needed.

Michelle Ying

Assistant Engineer

Distribution Circuits

Kum Shing (K.F.) Construction Company Limited

Kum Shing Group 金城營造集團