

Urgent Return receipt Expand Group Restricted Prevent Copy Confidential

**Jane Ching Kei LAU/PLAND**

---

寄件者: [REDACTED]  
寄件日期: 2024年11月05日星期二 10:46  
收件者: tpbpd/PLAND  
副本: Jane Ching Kei LAU/PLAND  
主旨: Re: Planning Application No. A/YL-MP/372 for Temporary Social Welfare Facility (Drug Dependent Persons Treatment and Rehabilitation Centre)  
類別: Internet Email

To whom it may concern,

In order to complete all the outstanding questions from FSD, two-month deferment is needed.

Thank you for your attention.

Quebeca

----- Message from Jane Ching Kei LAU/PLAND <[jcklau@pland.gov.hk](mailto:jcklau@pland.gov.hk)> -----

Date: Mon, 28 Oct 2024 10:19:19 +0000

From: Jane Ching Kei LAU/PLAND <[jcklau@pland.gov.hk](mailto:jcklau@pland.gov.hk)>

Subject: Re: [Urgent Follow-up Please] Planning Application No. A/YL-MP/372 for Temporary Social Welfare Facility (Drug Dependent Persons Treatment and Rehabilitation Centre)

To: [REDACTED]

Cc: [REDACTED]

Dear Ms. Yu,

In relation to your further information submitted on 2.10.2024, please find below comments from Fire Services Department on the revised FSI proposal for your follow-up:

**Comments from Fire Services Department (Contact Person: Mr. CHEUNG Wing-hei at 2733 7737 or Mr. YUEN Tsz-fung at 2733 7781)**

- i. Schematic drawings will not be vetted at this stage and shall be omitted;
- ii. Modified hose reel system shall be provided in accordance with the Code of Practice for Minimum

Urgent Return receipt Expand Group Restricted Prevent Copy Confidential

Fire Service Installations and Equipment 2022;

iii. Fire alarm system shall be provided in accordance with BS 5839-1:2017 and the FSD Circular Letter No. 6/2021;

iv. Visual fire alarms shall be provided in accordance with BS 5839-1:2017, the FSD Circular Letter No. 2/2012 and follow the *Design Manual: Barrier Free Access 2008* published by the Buildings Department;

v. Emergency lighting shall be provided in accordance with BS 5266-1:2016, BS EN 1838:2013 and the FSD Circular Letter No. 4/2021;

vi. Emergency lighting shall be provided in every compartment of each structure;

vii. Sufficient directional and exit signs shall be provided in accordance with BS 5266-1:2016 and the FSD Circular Letter No. 5/2008; and

viii. Fire detection system shall be provided in accordance with BS 5839-1:2017 and the FSD Circular Letter No. 6/2021.

Please contact the undersigned or the subject officer with contact detailed stated above should there be any questions. Thank you.

Best Regards,  
Jane LAU  
FSYLE DPO  
Planning Department  
Tel.: 3168 4051